



LEGENDA:

- TUBULATURA EVACUARE
- TUBULATURA ADMISIE
- D1 DIFUZOR TIP JET DIAMETRUL DE RACORD 250 MM
- G1 GRILA CU DUBA REFLEXIE SI LAMELE REGLABILE TUBULATURA RECTANGULARA 400 X200MM

NOTA

TOATA TUBULATURA VA FI IZOLATA ANTICONDENS CU O IZOLATIE DE 25MM

CATEGORIA DE IMPORTANTA: "B" CLASA DE IMPORTANTA: "II" GRADUL DE REZISTENTA LA FOC: "III"

VERIFICATOR EXPERT	NUME	SEMNTURA	CERINTA	REFERAT NR./EXPERTIZA NR./DATA
	B.C. VIA PRO IT CONSULTING S.R.L. BTR. PRIMAVERII, NR. 28, SC. B, ET.4, AP.18, BOTOSANI, JUDETUL BOTOSANI, C.U.I. 27399915; E-MAIL: VIAPROIT@GMAIL.COM TEL.: 0753/897.407			BENEFICIAR: UAT MUNICIPIUL BOTOSANI DENUMIRE PROIECT: MODERNIZAREA SI DOTAREA COLEGIULUI NATIONAL "A.T.LAURIAN" DIN MUNICIPIUL BOTOSANI
	SCARA: -			AMPLASAMENT: JUD. BOTOSANI, MUN. BOTOSANI, STR. NICOLAE IORGA, NR.19, NR. CAD 54743
SEF PROIECT COMPLEX	ARH. RANJA DAN-CRISTIAN		DATA: 2025	TITLUL PLANSEI: INSTALATII H.V.A.C. -VENTILARE- DETALIU VENTILARE AULA
PROIECTAT	ING. IOANA COJOCARIU			
DEBENAT	ING. IOANA COJOCARIU			
				FAZA: P.TH+D.E. NR. PROIECT: 11/2025 NR. PLANSA: IV.07 REV.0