

TRANSLATION from the Romanian language

Energy Audit

Highschool building within the Technical Energy College
from Electricienilor street, no. 1, Sibiu municipality

Beneficiary:
Sibiu City Hall
Illegible signature, Official stamp

Drafted by:
Energy auditor for buildings
eng. Pricopie Andrei Gheorghe
eng. Cruciat Radu
Illegible signature, Official stamp

CONTENTS

	Page
A. ANALYSIS REPORT AND ENERGY CERTIFICATION.....	3
1. General information regarding the building	3
1.1. Architectural structure and thermal insulation items.....	5
1.2. Strength structure items	5
1.3. Heating and hot running water systems	6
1.4. Ventilation systems	6
1.5. Air conditioning/cooling systems.....	6
1.6. Lighting systems.....	6
2. Building energy performance evaluation.....	6
2.1 Determination of the corrected thermal strength of the building items; how the thermal and energy performance requirements are met....	6
2.1.1. Geometric characteristics of the building's thermal envelope.....	7
2.1.2. Thermotechnical characteristics of the building materials.....	7
2.1.3. Unidirectional thermal strength and corrected for the effect of end attics, of the construction items of the end envelope of the building	7
2.1.4. Operating schedule, definition of calculation formula and zoning	8
2.1.5. Need for ventilation air	10
2.1.6. How the recommended thermal performance requirements are met in terms of thermal strength and hygrothermal comfort.....	10
2.2 Determining the annual primary energy consumption for heating.....	10
2.3 Determining the annual primary energy consumption for cooling	18
2.4 Determining the primary energy consumption for the preparation of hot running water.....	20
2.5 Determining the annual primary energy consumption for mechanical ventilation.....	21
2.6 Determining the annual primary energy consumption for lighting	21
2.7 Determining the annual primary energy consumption from renewable energy sources.....	22
2.8 Determining the annual primary energy consumption, quantities of equivalent CO ₂ emitted and the RER indicator.....	23
3. Development of the energy performance certificate	23
3.1 Mentioning the energy features of the reference building.....	24
3.2 Energy performance certificate	25
B. ENERGY AUDIT REPORT	26
4. Description of thermal refurbishment/modernization solutions.....	26
4.1. Presentation of building thermal refurbishment solutions and packages.....	26
5. Analysis of the economic efficiency of intervention works	33
5.1. Economic calculation premises	34
5.2. Economic efficiency indicators used in the economic analysis of the solutions	35
C. Conclusions	41
D. Recommendations for the owners.....	44
E. Bibliography.....	44
F. ENERGY ANALYSIS SHEET.....	46
G. Photo Annex.....	53
H. Other annexes.....	55

Illegible signatures, Official stamps

Energy Audit Report of the building
Gf+2F Highschool building within the Technical Energy College from Electricienilor street,
no. 1, Sibiu

A ANALYSIS REPORT AND ENERGY CERTIFICATION

1. General information regarding the building

The scope of the works consists into the thermal-energy evaluation of the Highschool building within the Technical Energy College located in Sibiu municipality, Electricienilor street number 1. Its height regime is ground floor and two floors.

The evaluation was carried out based on:

1. Survey of the studied building prepared by ALLBIZZ SRL
2. Cadastre of the studied building.
3. Inspections carried out during on-site visits.
4. Photo survey.
5. Investigations carried out on-site to establish the envelope structure.
6. The initial standard project carried out by IPCT in 1966

The results obtained based on the energy evaluation of the building and its heating, hot water preparation and lighting installations serve for the Energy Certification of the building, as well as for the preparation of the Energy Audit Report which includes the technical solutions for the refurbishment/modernization of the construction items and installations related.


The energy audit is carried out in order to evaluate the possibilities of improving the energy performance of the building, given the context of the refurbishment and modernization works of the Highschool building of the Technical Energy College.

1.1. Architectural and thermal insulation elements

The building is located in the municipality of Sibiu, Str. Electricienilor, no. 1, and was built in five sections.

The High School building of the Technical Energy College, located in Electricienilor Street, no. 1, Sibiu municipality, is made of four sections with the height regime Gf+2F. The building was designed by Electromontaj Trust by adapting the I.P.C.T. High School standard project with 20 classes, from 1966 and was built in the immediate following period.

The high school has a complex shape in plan that approaches the shape of an L with the long side facing Electricienilor Street and the short side facing Semaforului Street. The structure is divided into 4 sections according to the following sketch:



Section A, consisting of two building blocks. A1 and A2 separated by a settlement joint, is a regular section with a rectangular shape in plan with a length of 57 m and a height of approximately 10.9 m. The section is divided into two openings, one in which the 4.27 m hall is organized and one in which the 6.57 m classrooms are organized. The spans are all 3 m each. A classroom is arranged on three spans of 3 m each. Starting from the end facing Vasile Aaron Street, in the first span there is a sanitary group followed by 4 classrooms each organized in 3 spans. In the next 2 spans there is a reading room and the access hall to the high school. In the last 4 spans the secretariat, archive and the principals' offices were organized.

Section B also has an almost regular shape that can be classified as a rectangle with dimensions of 21.5 m x 13.39 m. The block is composed of a 6.57 m opening where classrooms are organized, a 2.75 m opening in which a hall is organized and a 3.77 m opening in which a stairwell, storeroom and cabinets are organized. Section B is separated by a seismic joint from section A. Section B is organized in 7 3 m spans.

Section C is arranged towards Vasile Aaron Street and is organized in an L shape. The body is composed of a classroom and a laboratory. A corridor and a stairwell are provided towards the center of the body. The body maintains the organization in 3 m spans of the other bodies from which it is separated by a seismic joint.

Outside the mentioned sections on the SE side of the high school, adjacent to section B, there is positioned its thermal power plant, a body with a height regime P. The section has an irregular shape that is inscribed in the plan in a rectangle with dimensions 14.1x13.1 m

The building is provided with a technical channel in which the pipes for distributing the thermal agent are arranged. In front of the classrooms, technical channels are provided through which the pipes serving each classroom are passed.

The main access to the building body is made on the SW side parallel to Electricienilor Street. Outside it, there is another access located on the opposite facade.

Height regime: ground floor and 2 floors for the bodies that make up the high school and ground floor for the thermal power plant body.

The high school body is an independent building that does not border other buildings. From an architectural point of view, the envelope is made up of:

- masonry walls with thicknesses of 30 cm;
- PVC windows with double glazing;
- ground slab composed of screed and reinforced concrete slab
- floor over the 2nd floor made of reinforced concrete.
- floor over technical channel made of reinforced concrete.

The building's strength structure is made of load-bearing masonry walls provided on both directions of the structure.

Energy Audit Report of the building

High school building within the Technical Energy College from Electricienilor street, no. 1, Sibiu. The height regime of the building body is +12.37 m from the +0.00 m elevation, represented by the floor elevation. The building is equipped with two stairwells.

The building's roof is made in the form of a wooden frame with a ceramic tile covering made in several waters. The roof of the thermal power plant is of the non-circulatory terrace type.

The roof of the high school is made between elevations +10.95 and +15.51 m, considering the +0.00 m elevation as the ground floor elevation. The elevation the floor is located approximately 60 cm above the level of the landscaped land.

Through the design topic, the beneficiary requests the implementation of energy efficiency measures, repairs to damaged elements, the complete modernization of the exterior finishes, the replacement/repair of the heating system, the preparation of hot running water and the existing artificial lighting.

The works will lead to the improvement of the operating conditions, by:

- improving the interior comfort conditions;
- reducing energy consumption;
- reducing maintenance costs for heating, hot running water, mechanical ventilation and lighting;
- rational use of the interior space in accordance with the regulations in force;
- increasing the hygrothermal comfort in the building;
- achieving the specific requirements of the space intended as an educational unit

1.2 Strength structure items

The architectural part comprises 4 bodies. Bodies A and B are regular bodies with a rectangular shape in plan. They are provided with a corridor and generally with classrooms arranged in 3 bays of 3 m each. Body C has a plan shape that approaches the shape of an L.

According to the technical expert report, the structural system is a dual one, made of load-bearing masonry walls that work together with reinforced concrete frames.

The frames are generally provided at a distance of 3 m and the masonry walls are provided between the classrooms and along the hallway.

The perimeter closures are 30 cm thick and the interior ones are 25 cm and 12.5 cm. The additional frame has a resistance structure in the form of a wooden structure, over which there is a ceramic tile covering.

The technical condition of the building is proper, with some local deficiencies (degraded exterior plaster, leaky joinery, the sidewalks around the building are detached from the building and have a reverse slope, the base has seepage). The frame of the building was built after the construction.

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu

1.3 Heating and hot running watersystems

The building has all utilities: electricity, water and sewage, gas.

The building is equipped with internal heating systems. There is a special room in the building serving as a central heating plant between axes 23 and 24 and axes N-M where the heating and hot water production system is installed. The heating system consists of two Viessman Vitoplex 100 heating plants. The same heating plants are used for the production of hot water.

The heating distribution system consists of a network of pipes located in the technical channel that connect the heating plants to the steel radiators

The radiators in the rooms are equipped with classic taps.

1.4 Ventilation systems

The building is not equipped with organized ventilationsystems.

1.5 Air conditioning/cooling systems

Not applicable. The building is not equipped with installations to ensure air conditioning.

1.6 Lighting systems

Artificial lighting is provided by fluorescent lighting fixtures..

2. Building energy performance evaluation

2.1 Determination of the corrected thermal strenghts of the construction elements of the building; how the thermal and energy performance requirements are met

2.1.1 Geometric characteristics of the building's thermal envelope

The geometric characteristics of the building were determined according to the methodology depending on the construction elements and are presented in the table below:

Energy Audit Report of the building:
 Highschoolbuilding withinthe Technical Energy College fromElectricienilor street, no.1 Sibiu county

Construction element	S [sqm]
Exterior masonry wall 30 cmthick	1618.1
Slab on the ground	324.8
Floor abovethe last floor	1145.0
Floor above the thermal facility	151.9
Exterior carpentry	1136.7
Developed built area	5348.6

2.12 Thermal-technical characteristics of the construction materials

The thermal-technical characteristics of the building materials that make up the building elements are presented in the table below..

No crt.	Material name	Characteristics		Increase percentage	calculation thermal conductivity
		p	γ		
		[kg/m ³]	[W/mK]		
1	Reinforced concrete	2400	1.62	1.1	1.782
2	Lime-cement mortar	1700	0.87	1.1	0.957
3	Cement mortar	1800	0.93	1.1	1.023
3	Solid brick masonry	1800	0.80	1.15	0.92
4	Simple concrete screed	2000	1.16	1.03	1.195
5	Fir wood	550	0.17	1.1	0.187
6	Gravel filler	1800	0.70	1	0.70
7	Top soil	1800	1.160	1	1.16
8.	Coalash and slag	650	0.290	1.1	0.319

2.13 Unidirectional thermal strengths and corrected with the effect of thermal attics, construction elements of the building thermal envelope

The unidirectional thermal strengths are determined by using the following formula:

$$R = R_{si} + \sum \frac{\delta_j}{a_j \lambda_j} + R_{se} = \frac{1}{h_i} + \sum \frac{\delta_j}{a_j \lambda_j} + \frac{1}{h_e} \left[\frac{m^2 K}{W} \right]$$

Energy Audit Report of the building:

Highschoolbuilding withinthe Technical Energy College fromElectricienilor street, no.1 Sibiu county

- h_i - internal surface heat transfer coefficient [W/m^2K];
- h_e – external surface heat transfer coefficient [W/m^2K];
- a - thermalconductivity increase coefficient depending on the condition and age of the materials, acc.to page 2.2, Mc001 Chapter 2.1.;
- γ – regulated thermal conductivity

The calculation of the corrected thermal strength is carried out according to the formula:

$$R' = rR$$

- R- the unidirectional specific thermal strength related to the areaA,
- R' – corrected thermal strength ;
- r- correction coefficient for thermal attics;
- S= envelope elements area

Construction element	S [sqm]	R [sqmK/W]	R [-]	R' [sqmK/W]	R' min [sqmK/W]
NE masonry exterior wall	474.1	0.507	0.72	0.37	3.00
NW masonry exterior wall	281.4	0.507	0.75	0.38	3.00
SW masonry exterior wall	487.4	0.507	0.71	0.36	3.00
SE masonry exterior wall	375.2	0.507	0.77	0.39	3.00
Floor slab	972.1	0.545	0.91	0.50	4.50
Floor over technical channel	324.8	0.357	0.97	0.35	4.50
Floor on theground floor under the attic	1145.0	0.623	0.93	0.58	5.00
PVC NE Exterior windows	365.9	0.43	1	0.43	0.83
PVC NE Exterior doors	14.0	0.41	1	0.41	0.77
PVC NW Exterior windows	235.2	0.43	1	0.43	0.83
PVC NW Exterior doors	7.2	0.41	1	0.41	0.77
PVC SW Exterior windows	343.7	0.43	1	0.43	0.83
PVC SW Exterior doors	14.1	0.41	1	0.41	0.77
PVC SE Exterior windows	149.4	0.43	1	0.43	0.83
PVC SE Exterior doors	7.2	0.41	1	0.41	0.77

The last column in the table with R'min represents the minimum required strength provided by the norm for buildings with school function - Corrected thermal strenghts recommended for the renovation of existing non-residential buildings (according to page 2.9.b Mc001-2022). It is noted that the thermal strenghts of the envelope elements are lower than the minimum strenghts requested by the rule.

2.1.4 Operating schedule, definition ofthe calculation formula and zoning

The building functions as a highschool with an operating schedule of 8 hours per day, 5 days per week, from Monday to Friday according to the table below:

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,

		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	No.of days	Week	Month
September	W24								20		200
	W25	10	10	10	10	10				50	
	W26	10	10	10	10	10				50	
	W27	10	10	10	10	10				50	
	W28	10	10	10	10	10				50	
		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	No.of days	Week	Month
October	W28								20		200
	W29	10	10	10	10	10				50	
	W30	10	10	10	10	10				50	
	W31	10	10	10	10	10				50	
	W32	10	10	10	10	10				50	
		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	No.of days	Week	Month
November	W32	10	10	10	10	10			25	50	250
	W33	10	10	10	10	10				50	
	W34	10	10	10	10	10				50	
	W35	10	10	10	10	10				50	
	W36	10	10	10	10	10				50	
		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	No.of days	Week	Month
December	W36	10	10	10	10	10			15	50	150
	W37	10	10	10	10	10				50	
	W38	10	10	10	10	10				50	

2.1.5 The need of air for ventilation

The building is not equipped with an organized ventilation system. Manual ventilation of the rooms, especially the classrooms, is carried out by unscheduled opening of the windows. At the same time, ventilation will also be carried out by air infiltration from the outside.

2.1.6. How the recommended thermal performance requirements are met in terms of thermal strength and hygrothermal comfort

The building does not comply with the recommended thermal performance requirements in terms of thermal strength and hygrothermal comfort.

2.2 Determination of the annual primary energy consumption for heating

The annual energy consumption for heating is determined according to Chapter 3 of MC001-2022, depending on the external and internal climatic parameters.

External climatic parameters

Conventional external calculation temperature


For winter, the conventional calculation temperature of the external air is considered depending on the climatic zone where the locality Sibiu is located (zone III), according to the MC001-2022 Methodology, Chapter 2.1.1, as follows:

$$\Theta_e = - 18^{\circ}\text{C}$$


Energy Audit Report of the building:
 Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,

CLIMATE DATA for Sibiu


Monthly average values & monthly maximum values ofthe exterior temperature [°C]



Monthly average values ofthe relative humidityofthe external air [%]



Monthly average values ofthe solar radiation intensity[w/sqm]



Interior climate parameters

The interior temperature for calculating the building while using has the following value: $\theta_{i,u} = 20$ [°C]

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu

Calculation of heat loss coefficients Htr and Hve

Calculation of the building's heat loss coefficient through ventilation, Hve

$$H_{ve} = \frac{\rho_a c_a n_a V b_{ve} f_{ve}}{3.6}$$

- ρ_a - air density;
- c_a - specific air heat;
- n_a - average number of air changes
- V - heated volume
- b_{ve} air inlet temperature is the outside air temperature
- f_{ve} correction factor for monthly calculation.

Calculation of the heat loss coefficient of the building, by transmission, Htr

$$H_{tr\,final} = H_d + H_g + H_{iu} + H_a$$

H_d -direct heat transfer coefficient between heated spaces and the exterior through the building envelope $\left[\frac{W}{K}\right]$

H_g -heat transfer coefficient through the ground $\left[\frac{W}{K}\right]$

H_{iu} -heat transfer coefficient through transmission through unheated spaces $\left[\frac{W}{K}\right]$

H_{ve} - Heat transfer coefficient through ventilation $\left[\frac{W}{K}\right]$

H_a - heat transfer coefficient through transmission to adjacent buildings $\left[\frac{W}{K}\right]$

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street. no. 1. Sibiu

1	2101.1	$\theta_{int,inc}$ [°C]	$\theta_{int,tra}$ [°C]	$A_{use,z}$ [m ²]	Q [m ³ /h]	Thermal inertia class	Average
		20,0		3580,0	14290,2	14290,2	Cm,zi/Ause,zi [J/m ² ·K]
							165000

Code	A _{e,i} carpentry		A _{e,i} [m ²]	Orientare	r [-]	R' [m ² K/W]	U'i [W/m ² K]	Type of adjacent space	Adjacent area code	H _g [W/K]	H _d [W/K]	H _{iu} [W/K]	H _{ve} [W/K]
	Nr.	[m ²]											
1	PE1		474,1	NE	0,72	0,37	2,74	Ext.			1298,82		
2	PE1		281,4	NV	0,75	0,38	2,63	Ext.			739,99		
3	PE1		487,4	SV	0,71	0,36	2,78	Ext.			1354,02		
4	PE1		376,2	SE	0,77	0,39	2,56	Ext.			961,08		
5	PL attic		1145,0	ORIZ		0,58	1,72	ZT	ZTU1			1968,92	
6	PI - ground		972,1	ORIZ		0,50	2,01	Sol		556,14			
7	PI - technical channel		324,8	ORIZ		0,35	2,89	ZT	ZTU2			939,06	
8	FE-PVC	365,9	365,9	NE		0,43	2,33	Ext.			851,03		
9	UE-PVC	14,0	14,0	NE		0,41	2,43	Ext.			34,00		
10	FE-PVC	235,2	235,2	NV		0,43	2,33	Ext.			546,88		
11	UE-PVC	7,2	7,2	NV		0,41	2,43	Ext.			17,51		
12	FE-PVC	343,7	343,7	SV		0,43	2,33	Ext.			799,27		
13	UE-PVC	14,1	14,1	SV		0,41	2,43	Ext.			34,25		
14	FE-PVC	149,4	149,4	SE		0,43	2,33	Ext.			347,51		
15	UE-PVC	7,2	7,2	SE		0,41	2,43	Ext.			17,51		4715,77
16	PI-central		151,9	ORIZ	0,8	0,26	3,87	Ext.		556,14	7589,70	2907,97	4715,77
17													
18													
19													
20													
21													

Legend: PE – exterior wall; PL – floor; FE – exterior windows; UE – exterior doors

LOSSTO THE GROUND		Thermal features				Thermal flow features						
Exposed area [m]	Walls thickness [m]	α wf [W/mK]	γ g [W/mK]	P c [W/mK]	$\bar{\sigma}$ (m)	α	β	r	Θ_{int} [C]	Θ_{int} [K]	Θ_e [C]	Θ_e [K]
281.00	0.30	1.68	0.3	1.26E-0.6	2.20	0	1	1	16.9	3.4	9.1	11.4

	Jan	Feb	Mar	Apr	Mai	Jun	Jul	Aug	Sep	Oct	Noi	Dec	
$\theta_{int,inc}$ [°C]	20,0	20,0	20,0	20,0	20,0	20,0	20,0	20,0	20,0	20,0	20,0	20,0	HEATING
$\theta_{int,tra}$ [°C]													COOLING
$\theta_{int,ad}$ [°C]													
θ_{ext} [°C]	-23	-0,3	3,8	9,7	15,2	18,5	20,1	19,2	14,0	9,2	3,6	-1,5	
b [-]	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	
H _{ia} [W/K]													Max
H _a [W/K]	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,0
H _g [W/K]	556,23	574,33	585,55	588,89	583,46	570,70	554,05	537,95	526,73	523,39	528,82	541,58	
H _u [W/K]	1298,18	1298,18	1298,18	1298,18	1298,18	1298,18	1288,18	1298,18	1298,18	1298,18	1298,18	1298,18	1298,2
H _v [W/K]	9446,11	9462,21	9473,43	9476,77	9471,34	9458,59	9441,93	9425,84	9414,61	9411,27	9416,71	9429,46	9476,8

HEATING		COOLING		DECREASED WEEKEND		RACRE		HEATING EFFICIENCY		HEATING EFFICIENCY	
$\Delta t_{H,red,y}$	12	$\Delta t_{H,red,y}$		$\Delta t_{H,red,y}$	48	$\Delta t_{C,red,wind}$		$\eta_{H,ind}$		LOW	
$\eta_{recovery}$	5	$\eta_{recovery}$		$\eta_{recovery}$	1	$\eta_{recovery}$		$(\Delta x t)_{sup}$		$a_{H,0}$	0,8
$f_{H,red,y}$	0,36	$f_{H,red,y}$	0,00	$f_{H,red,y}$	0,29	$f_{C,red,wind}$	0,00	$\varphi V_{room} f_2$		$T_{H,0}$	70
						$\beta_{C,red,wind}$	1,00	$f_{D,H,C,25}$		H _{final} [W/K]	14192,54

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu
Internal intakes

Next, internal intakes are calculated basedon theoccupants and equipment located in the building.

1		ZTC1.1														
Type	Thermal power		User [W]	Operating period												
	Predefined Nr	[W]		Jan [zile]	Feb [zile]	Mar [zile]	Apr [zile]	Mai [zile]	Iun [zile]	Iul [zile]	Aug [zile]	Sep [zile]	Oct [zile]	Noi [zile]	Dec [zile]	
1	soft activity occupants	600	66950		21	21	31	21	31	30	21	0	28	28	30	21
2	lighting - linear fluorescent T26	600	18000		21	21	31	21	31	30	21	0	28	28	30	21
3	Desktop-type computers	50	17500		21	21	31	21	31	30	21	0	28	28	30	21
4																
5																
6																
7																
8																
9																
10																
11																
12																
13																
14																
15																
Total power and operating hours		102490	0		168,0	168,0	248,0	168,0	248,0	240,0	168,0	0,0	224,0	224,0	240,0	168,0

Legend: zile = days

Interior heat intakes													TOTAL	
	Jan [kWh]	Feb [kWh]	Mar [kWh]	Apr [kWh]	Mai [kWh]	Iun [kWh]	Iul [kWh]	Aug [kWh]	Sep [kWh]	Oct [kWh]	Noi [kWh]	Dec [kWh]	Type of source [kWh]	Annually [kWh]
1	11254,32	11254,32	16613,52	11254,32	16613,52	16077,60	11254,32		15005,76	15005,76	16077,60	11254,32	151665,36	
2	3024,00	3024,00	4464,00	3024,00	4464,00	4320,00	3024,00		4032,00	4032,00	4320,00	3024,00	40752,00	
3	2940,00	2940,00	4340,00	2940,00	4340,00	4200,00	2940,00		3920,00	3920,00	4200,00	2940,00	39620,00	
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
	17218,32	17218,32	25417,52	17218,32	25417,52	24597,60	17218,32	0,00	22957,76	22957,76	24597,60	17218,32		232037,36

Solar gains

Solar gains were calculated based on:

$a_{sol,k}$ radiation absorption coefficient

$g_{gl,n,wt}$ total solar energy transmission coefficient at normal incidence

$g_{gl,wt}$;- total average solar energy transmission coefficient

$F_{fr,win}$ -window frame surface fraction

$F_{sky,k}$ -visibility factor between element and sky

$F_{sh,dir}$ shading factor for direct solar radiation intensity

Energy Audit Report of the building:


Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,

The heat lost as a result of thermal radiation to the sky is:

$$Q_{sky,eli}=24492.4 \text{ KWh/year}$$

Need for heating

The table below presents the heating requirements for the highschool building for each month.



Determining the heating period

Next, the number of degree days for the winter period is established. The following graph shows the average monthly and external equilibrium temperatures. The external equilibrium temperature Θ_e is the external temperature for which it is not necessary to increase the heating.

$\Theta_h(tr,ve;sol,int,-)$ -Heat transferred by transmission for heating, ventilation, solar gains, internal gains

T_H -time constant of the heated area

Intermittent heating is taken into account through the γ coefficients.

1		ZTC1.1		H_{gr}/H_{tot}		336,86 [W/K]		Humidification													
Month	Hrs	$Q_{Htr, coal}$	$Q_{Hve, coal}$	$Q_{Hsk, coal}$	f_{Ht}	Q_{Hcool}	Q_f	Q_{Hcool}	Q_{Hskt}	Q_{Hgr}	Q_{Hve}	Q_{Hsk}	Q_{Hskt}	$\gamma_{Htr, coal}$	γ_{Ht}	a_{Ht}	η_{Hgr}	Q_{Hcool}	f_{Ht}	f_{Hsk}	Q_{Hcool}
[-]	[h]	[kWh]	[kWh]	[kWh]	[-]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[-]	[-]	[-]	[-]	[kWh]	[-]	[-]	[kWh]
Dec	150	28639	15208	44048	11,2	1267	1758	-481	17259	18798	18395	9151	27548	0,38	0,61	0,96	0,61	15594	1,00	0,12	0,0
Jan	150	29677	15774	45651	11,1	1751	1750	1	17259	17260	18905	9459	26423	0,38	0,61	0,96	0,61	16116	1,00	0,13	0,0
Feb	150	27471	14360	41831	11,1	2594	1895	899	17255	18154	18412	9126	27538	0,43	0,66	0,96	0,59	15109	1,00	0,12	0,0
Mar	230	34362	17571	51873	11,1	4299	2299	2000	25458	27458	25070	12248	37316	0,53	0,74	0,96	0,56	18708	1,00	0,15	0,0
Apr	150	15063	7286	22346	11,1	3024	1805	1419	17258	18877	13714	8508	26222	0,83	0,92	0,96	0,51	10252	1,00	0,08	0,0
Mai	250	12570	5899	18229	11,1	5035	2368	2177	25458	27835	12570	5659	18229	1,51	1,52	0,96	0,38	7461	1,00	0,06	0,0
Iun	220	4218	1566	5773	11,1	5000	2992	2307	24637	28945	4216	1558	5773	4,66	4,67	0,96	0,17	1083	0,13	0,01	0,0
Iul	150	0	0	0	11,2	3775	1856	1819	17259	19178	0	0	0	0,00	0,00	0,96	0,00	0	0,00	0,00	0,0
Aug	0	0	0	0	0,0	0	0	0	41	41	0	0	0	0,00	0,00	0,80	0,00	0	0,00	0,00	0,0
Sep	200	12291	5859	17920	11,2	4604	2579	2025	22907	25922	12291	5659	17920	1,39	1,40	0,96	0,41	7679	0,36	0,06	0,0
Oct	200	20822	10186	31008	11,2	4447	2558	1889	22909	24867	18583	8885	27488	0,90	0,91	0,96	0,51	13932	1,00	0,11	0,0
Noi	250	37296	19335	56601	11,2	3099	2942	257	24637	24894	25265	12363	37628	0,44	0,66	0,96	0,58	20648	1,00	0,16	0,0
Dec	150	28838	15208	44048	11,2	1267	1758	-481	17259	18798	18395	9151	27548	0,38	0,61	0,96	0,61	15594	1,00	0,12	0,0
		222444	333292	38924	24492	14431	332517	244944	187431	80412	248063			127581			0				

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,



The graph above shows:

Θ_e = monthly average external temperature, in Celsius degrees

Θ_{int} = monthly average internal temperature, in Celsius degrees

Θ_{emz} - monthly average equilibrium temperature, in Celsius degrees

From the intersection of the two graphs, the number of heating days is determined, namely 162.89 days.

Energy consumption for heating

The heating consumption is calculated according to the type of source, the regulation, distribution and transmission of the heating system. The heat losses through emission for the heating elements were calculated. The following table shows the results for the energy consumption through emission. Additionally, the auxiliary energy consumption given by the circulation pumps was taken into account.

Total heating emission energy calculation															
Heating emission energy consumption calculation											34154,893	[kWh _{yr}]			
Specific heating energy emission consumption											9,54	[kWh/m ² .yr]			
Total floor reference area											3580,00	[m ²]			
Equipments electric consumption control															
ZT1	2348,7	2418,9	3953,7	3235,0	5051,8	2346,1	0,0	0,0	4159,3	4192,4	4091,9	2357,2	34154,893	ZT1	0,000
TOTAL	2348,7	2418,9	3953,7	3235,0	5051,8	2346,1	0,0	0,0	4159,3	4192,4	4091,9	2357,2	34154,893	TOTAL	0,000

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,
Considering the previous data and the energy system, one calculated the energy consumption for heating:

	Jan	Feb	Mar	Apr	Mai	Iun	Iul	Aug	Sep	Oct	Noi	Dec
QH;dis,in [kWh]	18720,828	17772,878	24008,973	13883,051	12814,392	34814,94	0,000	0,000	11924,620	18388,065	25125,220	18204,770
QW;dis,in [kWh]	3275,072	3254,558	4889,532	5271,845	5270,602	5060,325	3221,542	172,741	4245,225	4258,375	5296,927	3273,231
QV;dis,in [kWh]	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000
QC;dis,in [kWh]	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000
Qge;out,tot [kWh]	0	0	0	0	0	0	0	0	0	0	0	0

The table shows the monthly calculation for heating, hot water consumption, ventilation, air conditioning and the total.

Total specific annual primary energy consumption for heating

Based on the heating consumption, the specific primary energy consumption of the building for heating can be calculated as:

$$q_{inc} = 60,3 \left[\frac{kWh}{\text{year} \cdot m^2} \right]$$

The building, from a heating point of view, falls into class C, with a specific annual primary energy consumption of 60.3 kWh/sqm per year.

2.3 Determination of annual primary energy consumption for cooling

The building is not equipped with an organized air conditioning system, in this case it is not mandatory to calculate the energy requirement for cooling (the building has no energy consumption for cooling). However, a calculation was made to determine the energy requirement for air conditioning and the overheating indicator.

Energy Audit Report of the building:

Highschool building within the Technical Energy College from Electricienilor street, no. 1, Sibiu

Freshair flow provided by the ventilation system from the building: m^3/h
0,00 vol/h

Ventilation system yield: %

Temperature range during the summer: 15.00 K

Ventilation ratio due to opening the windows during the night: vol/h

Number of overheating hours (temperature > 26 degrees) : 241 hours

Percentage of total yearly number of hours: 2.75 %

2.4 Determination of the primary energy consumption for preparing the hot running water Energy consumption evaluation for preparing the hot running water is made starting from the hot running water consumption for one person per day and depending on the activities carried out by such persons.

HOT RUNNING WATER ENERGY CONSUMPTION CALCULATION

General data

Water temperature data

Hot running water temperature: 60°C

Cool water temperature: 10°C

Temperature difference allowed: 5°C

Average temp: 57.5°C

Hot running water accumulation temp: 60°C

Burried pipes depth: (m)

Recirculation pipe: does not exist

General heating meter: does not exist

Does the hot running water system exist: Yes, it works

1. ZT1 Reference area: 3580.0 sqm
Living area: 0.0 sqm

Energy source for preparing the hot running water:
Own source (individual thermal plant): natural gas

Recirculation pump: NO Centralized heating with connection to a thermal point: local central

Type of equipments for preparing the hot running water: Boiler with accumulation 1 volume: 2000 l

Debit metres on the consumption points: do not exist Sanitary items

Daily schedule for hot running water: 8 hrs/day

WC: 25 Urinals: 9 Hot water consumption points: 19

Number of sanitary items uses: 100 l/day

Washbasins: 19 Cool water cons. points: 63

13. Schools without washers or bathrooms

a. Schools without washers or basins for one student per program

V _{day}	Days											
l/day	Jan	Feb	Mar	Apr	Mai	Jun	Jul	Aug	Sep	Oct	Noi	Dec
3517,0	15	15	23	25	25	24	15	0	20	20	25	15

Facilities supplied in local system

Systems equipped with single command remote controls

f- average number of daily consumption units = 609.00 [0]

Number of students: 600 people

V_{w,f,day} = specific need for one consumer : 5.00 l/unit,day

V_{w,day} = volume need of hot running water [3045.00] l/day

V_{w,l,day} = volume corresponding to water loss 471.98 l/day


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Noi	Dec
Number of hot running water consumption days - no recirculation	120	120	184	200	200	192	120	0	160	180	200	120
Number of operating days of the recirculation pump	120	120	184	200	200	192	120	0	160	180	200	120
Q _{w,nd} monthly [kWh/month]	3038,4	3038,4	4855,9	5080,7	5080,7	4858,3	3038,4	0,0	4048,6	4048,6	5080,7	3038,4

Q_{w,nd, annual, ZT1} 44939,080 [kWh/an]

Q_{w,nd, annual, spec., ZT1} 12,55 [kWh/m²,an]


Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,
 Total energy calculation for providing the necessary hot running water – SUMMARY



Energy consumption for preparation, distribution, storage and generation of hot running water

#	AREA	Q _{w,nd}	Q _{w,dis,tot}	Q _{w,sto}	Q _{w,g}	Q _{w,total}	W _w	Q _{w,total}	W _w	Q _{acc}	E _{acc}
um	[-]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh _{ep}]	[kWh _{ep}]	[kWh _{ep}]	[kgCO ₂]
1	ZT1	44939,080	389,368	2161,507	4858,001	52347,976	439,601	61247,131	1099,004	62346,135	12489,514
TOTAL		44939,080	389,368	2161,507	4858,001	52347,976	439,601	61247,131	1099,004	62346,135	12489,514



Q_{w,nd,total} **62346,135** [kWh/yr] Q_{w,nd,spec} **17,42** [kWh/m²,yr]
 CO₂ emissions **12489,514** [kgCO₂/yr] Specific CO₂ emissions **3,49** [kgCO₂/m²,yr]

The building, in terms of the preparation of hot running water, falls into class B, having a specific annual primary energy consumption of 17.42 kWh/sqm/year

2.5 Determining the annual primary energy consumption for mechanical ventilation

The building is not equipped with a mechanical ventilation system. According to Mc001-2022, for non-residential buildings for which ventilation is not provided by a dedicated centralized mechanical ventilation system, a virtual consumption of electricity for ventilation is required corresponding to a classification into energy efficiency class E - the maximum consumption limit, namely 39kWh/sqm/year in case of buildings destined for education.

2.6 Determining the annual primary energy consumption for lighting

The calculation of the energy requirement for lighting, in case of the building analyzed, is carried out starting from the power installed, which was estimated.

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

ZT code: ZT1 ZT area category: 04 – educational establishments ZT area destination: a-classroom

power estimated: yes

Floor reference area: 3580.00 sqm

Length, L: 358.00 [m]

Width, W: 10.00 [m]

Height, h_m : 3.30 [m]

Room index, K: 2.948 [-]

Lighting source distribution, UFF: 10%

Type of flow: direct

Power density per flow: 0.0221 [W/x]

Power density: 8.40 W/sqm

Estimated lighting power: 30070.40 W

Correction factor, F_{mf} : 1.33 [-]

Absence factor, F_a : 0.25 [-]

Power decrease factor, F_{CA} : 1.00 [-]

Source efficiency factor, F_L : 0.95 [-]

Lighting power known: 4400,0 [W]

Lighting level, E_m : 300 [lx]

Maintainance factor, FM: 0,6 [-]

Lighting area percentage: 100% [%]

Lighting charging batteries: No

Stand-by for lighting control: No

Type of lighting source: T26 linear fluorescent lamp

Occupation control: 1 – Manual On/Off

emergency light battery consumption: 0 [kWh/sqm.year]

stand-by energy consumption: 0 [kWh/sqm.year]

constant lighting factor, F_c : 1 [-]

control II dependency factor, F_{oc} : 1 [-]

occupation dependency factor, F_c : 0.95 [-]

Natural light dependency factor

Type of natural light control: Manual

Constantly controlled system: No

Natural light dependency factor, F_d : 0.544 [-]

Thermal area results – ZT1

- Usage hours/day: 1000

- Usage hours/night: 200

- Total usage hours: 2000

- Total electricity lighting annual consumption: 33690.370 [kWh/year]

- LENI (Preliminary) indicator: 9.41 [kWh/sqm.year]

Safety lighting charging power, P_{em} : 0.0 W

power lighting controls- P_{pc} : 0.0 W

W_{total} : 84225.925 [kWh/year]

CO₂ emissions: 9012.174 [kgCo₂/year]

Energy consumption for lighting

LENI: 23.53 [kWh/sqm.year]

Specific CO₂ emissions: 2.52 [[kgCo₂/sqm.year]

The building, from lighting point of view, falls into class C, with a specific annual primary energy consumption of 23.53 kWh/sqm. year.

2.7 Determining the annual consumption of primary energy from renewable energy sources

Not applicable

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

2.8 Determining the annual primary energy consumption, quantities of equivalent CO2 emitted and RER indicator

Energy consumption before refurbishment

Consumer	HEATING	HRW	VENTILATION	COOLING	LIGHTING	Energy from renewable sources	TOTAL
Final thermal energy consumption [MWh/year]	181.224	52.348	0.000	0.000	0.000	0.000	233.572
Final electricity consumption [MWh/year]	1.856	0.440	55.848	0.000	33.690	45.917	91.834
Primary energy consumption [MWh/year]	216.672	62.347	139.620	0.000	84.226	45.917	502.865
Specific energy consumption [kWh/sqm.year]	60.52	17.42	39	0	23.53	12.83	140.47
ENERGY EFFICIENCY CLASS	B	B	E	-	C	-	C

The primary energy consumed to ensure comfort in the building is determined, 140.47 kWh/sqm, year - CLASS C.

Based on the total annual consumption of thermal and electrical energy, the annual CO2 equivalent emissions are determined. The specific amount of CO2 is 22.2 kg/sqm. year.

The RER indicator is determined with the relationship

$$RER = \frac{E_{p,regen}}{E_p} \cdot 100 = 9.14\%$$

3. Drafting of the energy performance certificate

The building's energy performance certificate is drafted according to Mc001-2022. The actual building falls into energy efficiency class C.

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no.

3.1 Mentioning the energy features of the reference building

- The reference building is a virtual building associated with the real building that is being analyzed from the energy performance point of view. This concept allows the comparison of the thermotechnical and energy characteristics of the real building with the “reference” values.
- The reference building is defined as follows:
 - for the construction elements that are part of the building envelope, the recommended values of the corrected thermal strengths indicated in MC001-2022 table 2.9b for the current refurbished non-residential buildings are chosen (chapter 2.2.2.)
 - from the energy point of view, by the maximum primary energy consumption value indicated in MCOOI-2022 table 2.10b (chapter 2.3.) for buildings intended for the education system, climate zone III (82.70kWh/sqm.year), considering the building equipped with all technical systems (heating, hot running water, lighting, ventilation and cooling)
 - from the pollution level point of view, by the value of equivalent CO2 emissions indicated in MC001-2022 table 2.10b (chapter 2.3.), for buildings intended for the heating system. climate zone III (13.10 kgCO2/sqm. year), considering the building equipped with all technical systems (heating, hot running water, lighting, ventilation and cooling)

Reference building		
Primary energy consumption [kWh/sqm.year]		CO2 emissions [kgCO2/sqm.year]
Heating	82.70	13.10
Hot running water		
Cooling		
Ventilation		
Lighting		
Class	B	B

Energy Audit Report of the building:

Highschool building within the Technical Energy College from Electricienilor street, no.1 Sibiu county

3.2

ENERGY PERFORMANCE CERTIFICATE

drafted according to the Calculation Methodology of the Buildings Energy Performance no.001
 DATA REGARDING THE CPE AND THE ENERGY AUDITOR IDENTIFICATION

CPE number 000131/550311

Valid 10 years until 13.05.2025
 if no major changes appear

Cruciat Radu-Iuliu Energy auditor
 Certificate SSA/02258 grade I

DATA REGARDING THE BUILDING/BUILDING BLOCK CERTIFIED NZEBNO

Building category: school/highschool/college

Year of building/major refurbishment: 1966

Building address: Sibiu, Electricienilor street no.1, Sibiu county

Floor reference area: 3580.00 sqm

GPS coordinates (lat x long): 45.78454x 24.16796

Built/developed area: 1389/3835 sqm

Height regime: Gf+2F

Reference interior volume: 12678.00 m3

CPE drafting purpose: Information

Calculation programme used: ENER+ version 04/2024


ENERGY PERFORMANCE TRUE BUILDING REFERENCE BUILDING CO2 EMISSIONS LEVEL

kWh/sqm.year – total primary energy

kgCo2/sqm.year

High energy performance

Low pollution level



Total annual specific energy consumption (kWh/sqm.year)	Final	65.1	25.7	CO2 equivalent emissions level (kgCo2/sqm.year)	22.2
	primary	140.3	82.7		

low energy performance

high pollution level

Annual specific energy consumption from renewable sources (Kwh/sqm.year)	Thermal solar	Electric solar	Heat pumps	Biomass	Other SRE type	Total SRE
	0.0	0.0	0.0	0.0	12.8	12.8

Type of installation system true building	Energy class / Annual specific consumption of primary energy per utility (kWh/m², η)*												
	A+	A	B	C	D	E	F	G					
Heating	≤ 26	26 - 35	35 - 60.3	60.3 - 71	71 - 144	144 - 218	218 - 272	272 - 327	327 - 372	372 - 427	427 - 482	482 - 537	> 537
Hot running water	≤ 7	7 - 10	10 - 17.4	17.4 - 19	19 - 26	26 - 33	33 - 41	41 - 49	49 - 57	57 - 65	65 - 73	73 - 81	> 81
Cooling ***	≤ 4	4 - 6	6 - 13	13 - 22	22 - 31	31 - 38	38 - 46	46 - 54	54 - 62	62 - 70	70 - 78	78 - 86	> 86
Mechanical ventilation	≤ 4	4 - 6	6 - 11	11 - 21	21 - 31	31 - 39.0	39.0 - 46	46 - 54	54 - 62	62 - 70	70 - 78	78 - 86	> 86
Lighting	≤ 7	7 - 10	10 - 21	21 - 23.6	23.6 - 33	33 - 45	45 - 57	57 - 68	68 - 80	80 - 92	92 - 104	104 - 116	> 116

*values calculated ***number of hours of a year when the interior temperature exceeds the comfort temp.

**t/ethermal/electric in free regime, during the summer = 241h (is 0 if the cooling consumption is calculated)

Auditor's signature and stamp

B. ENERGY AUDIT REPORT

4. Description of the thermal refurbishment/modernization solutions

Following the assessment of the current situation, one observes that the envelope elements do not comply with the minimum requirements set out in the Methodology for calculating the indicative energy performance of buildings Mc 001-2022, approved by ordinance no. 16/2023.

The measures provided by the energy audit aim to bring the construction within the minimum requirements established by Mc001-2022 and to meet the eligibility conditions requested for accessing funds through the Swiss-Romanian Cooperation Program for Energy Efficiency and Renewable Energy, namely Supporting the Transformation of Current Public Buildings into NZEBs.

According to the specific guide - Conditions for accessing funds are:

- In order to ensure the energy performance of the building, the financing will target the in-depth energy renovation of public buildings (primary energy savings of over 60%).
- Upon the investment completion, the building refurbished should obtain the A or B energy performance certificate

According to the specific guide - the eligible intervention works are:

thermal refurbishment works of the building envelope elements;
thermal refurbishment works of the building envelope
thermal refurbishment works of the heating system/hot running water supply system;
installation of alternative systems for producing electricity and/or heat for own consumption; use of renewable energy sources;
installation/refurbishment/modernization of air conditioning systems to ensure indoor air quality;
refurbishment/modernization works of lighting systems in buildings;
integrated energy management systems for buildings;
intelligent shading systems for the hot season;
modernization of technical systems of buildings;
provision of charging stations for electric cars, according to the provisions of Law no. 372/2005 on the energy performance of buildings, republished;

4.1. Presentation of solutions and packages for the thermal refurbishment of the building

Solution 1. This solution will improve the thermal strength of the envelope elements, namely exterior walls, floor above the last floor and floor above the technical channel.

The thermal insulation of the exterior walls with a layer of fireproof expanded polystyrene or mineral wool 15 cm thick on the exterior. It is recommended that the thermal insulation used has a thermal conductivity of $\gamma < 0.038$ W/mK

Energy Audit Report of the building:

Highschool building within the Technical Energy College from Electricienilor street, no. 1, Sibiu

By applying the solution, an increase above the minimum level of thermal transfer strength of the opaque part of the envelope will be achieved. Also, applying the solution will lead to the correction of thermal attics. The base of the structure will be thermally insulated with fireproof extruded polystyrene boards at least XPS300 thick of 5-10 cm.

Thermal insulation of the floor above the last floor with natural sheep wool insulation with a thickness of 25 cm and a minimum thermal strength of $\gamma < 0.038$ W/mK.

Thermal insulation of the floor above the technical channel with polystyrene or mineral wool thick of 10 cm. We recommend that the thermal insulation used to have a thermal conductivity of $\gamma < 0.038$ W/mK.

Solution 2. Replacing the external double-glazed windows and doors with aluminum or PVC carpentry, with frames and sashes provided with pentachamber profiles and galvanic metal reinforcement profiles, triple thermal insulation windows treated on the outside with low-e. Two sealing gaskets will be provided between the frame and the sashes and on the contour of the thermal insulation windows.

By replacing the carpentry, the final strength of the windows and doors will be increased above the minimum level, cold air infiltration will be reduced, and thermal attics at the contact between the window and door frames with the closing walls will be improved. The new windows will have a minimum thermal strength of $R_{min} = 0.83$ sqm K/ W (or a transfer coefficient lower than $U = 1.2$ W/sqm K) and respectively $R_{min} = 0.77$ sqm K/ W (or a transfer coefficient lower than $U = 1.3$ W/sqm K) for doors.

Solution 3. The solution refers to the building's installations.

3.1. In order to increase the efficiency of the heating system, a condensing gas boiler will be installed in the current thermal plant. It will serve for overtaking the eventual consumption peaks, the building heating following to be made mainly by using heat pumps.

3.2. A air-water heat pump will be installed. The boiler will be used to take over the consumption peaks during the winter and will be adjusted as to prioritize as much as possible the use of heat pumps. The calculation took into account one heat pump with COP4. We recommend to change the thermal agent distribution network and we also recommend to replace the used static bodies with new ones.

3.3. A system of 90 photovoltaic panels (36 kWh) will be arranged on the roof structure, on SW and/or SE directions that will produce electricity for the lighting system, for the heat pumps, and for preparing the hot running water. The photovoltaic panels will be connected to the national network in order to benefit from a compensation according to the regulations in force.

3.4. Ventilation will be made in an organized manner. Ventilation systems will be provided with heat recovery in each class. They have been calculated for an efficient heat recovery of 72%.

3.5. The lighting fixtures will be replaced with some led fixtures. Once with these changes one will inspect the electrical system condition and if it shows damages, they will be repaired. We recommend to use the presence sensors for the circulation areas.

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

Related works. The following is a brief description of the related works that will be carried out together with the main thermal refurbishment works:

- Local repair of the existing envelope elements that pose a risk of detachment.
- Repair of any leaks in the framework. If necessary, the framework elements will be replaced or reinforced.
- The rainwater collection systems of the framework will be repaired or replaced.
- The installations and equipment installed on the building facades will be dismantled and reassembled.
- The protective sidewalks around the building will be repaired or replaced in order to remove any infiltrations to the foundations and basement of the building.
- Water losses from the installations will be removed. If necessary, the cold water distribution installations, household and rainwater sewer collectors up to the connection/connection shaft will be repaired/replaced.
- The current thermal and waterproofing layers will be removed.
- The prefabricated roof will be removed from the area where the ventilation-heating device will be installed and a steel support structure will be provided.

For the economic calculation, the following packages are proposed:

Package 1 is a package consisting into the implementation of solutions 1 and 2. Within the package, the thermal insulation of the exterior walls with a 15 cm thermal insulation layer is carried out, the thermal insulation of the floor above the ground floor with a 25 cm thermal insulation layer, the thermal insulation of the floor above the technical channel with a 10 cm thermal insulation layer and the replacement of the existing carpentry.

The corrected, recalculated thermal strengths of the construction elements in case of applying package 1 are synthetically presented in Table 1.

Table 1

Construction element	S [sqm]	R [sqmK/W]	R'min [sqmK/W]	Criteria Fulfilled
NE exterior masonry wall	474.1	3.03	3.00	YES
NW exterior masonry wall	281.4	3.12	3.00	YES
SW exterior masonry wall	487.4	3.08	3.00	YES
SE exterior masonry wall	375.2	3.21	3.00	YES
Ground slab	972.1	0.53	4,50	NO
Floor over the last floor below the attic	1145.0	5.86	5.00	YES

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,

Flooring over thetechnical channel	324.8	2.66	2.50	YES
NE exterior windows	365.9	0.83	0.83	YES
NE exterior doors	14	0.77	0.77	YES
NW exterior windows	235.2	0.83	0.83	YES
NW exterior doors	7.2	0.77	0.77	YES
SWexterior windows	343.7	0.83	0.83	YES
SWexterior doors	14.1	0.77	0.77	YES
SE exterior windows	149.4	0.83	0.83	YES
SE exterior doors	7.2	0.77	0.77	YES

The ground slab does not comply with the minimum strengthspecified by the code. The works related to the energy improvement of these parts of the envelope are expensive and not economically justified.

Package 2 is a package consisting of the implementation of package 3. This package consists of the refurbishment of the installations, namely: heat pumps, a new heating plant, a ventilation system with heat recovery and a photovoltaic panel system were installed. Additionally, the package includes measures to improve the lighting system. In order for the solution package to meet the minimum requirements given by the calculation methodology, the use of renewable sources and the introduction of a mechanical ventilation system for the investigated building are requested.

A photovoltaic panel system with an installed power of 36 kWh is implemented. The calculation considered a number of 90 photovoltaic panels on the roof of the high school to reduce the consumption of electricity for the operation of heat pumps, a hot running water preparation plant and the lighting system. Polycrystalline photovoltaic panels with a maximum power of 400 W were used for the calculation. The photovoltaic panels are mounted on the SE or SW side of the roof of the high school building. To determine the electrical energy produced by the photovoltaic panels, the position of the building, the cardinal orientation on which the panels are mounted and their inclination to the horizontal were taken into account.

The following table presents in order:

I_i Solar radiationon a horizontal surface;

f_{head} - correction factor of the global intensity of solar radiation function of the inclination angle of the solar collectors and the angle of deviation from the cardinal direction SOUTH

$I_{i,inc}$ It inclined- solar radiation on an inclined surface;

E_{li} total lunar energy



Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu

CALCULATION OF ENERGY PRODUCED BY THE PHOTOVOLTAIC PANELS

Thermal area related to the photovoltaic solar system: ZT1

Entry data photovoltaic system

Type of panel: 400 Wp Monocrystalline Yield = 21%

Maximum electrical power: 400 W

Nominal yield: 21%

Solar panel area: 2.11 sqm

Number of solar panels: 90

Total electrical power: 36.000,0 W

Nominal temperature: 45°C

Module temperature coefficient: 0.4%

Energy loss expressed in percentages:

Dust: 0.01% Age: 0.1%

Initial degradation: 0.1%

Availability: 1%

Inverter loss: 10%

Shadowing: 0.25%

Cables: 0.2%

Producer: 0.15%

FV panels: 0.2%

Snow: 0.5%

Connections: 0.1%

Imperfections: 0.2%

Total energy loss: 2.81%

Installation method: onthe building


Calculation method: complex

Panels orientation: SW

Inclination angle: 36%

ENERGYPRODUCTION RESULTS

	Jan	Feb	Mar	Apr	Mai	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
$H_{r,inc}$ [W/m ²]	45,4	78,3	119,1	162,0	195,9	216,1	228,1	199,8	154,7	109,9	54,1	32,9	1598,3
$H_{r,inc,0}$ [W/m ²]	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00
$H_{r,inc,1}$ [W/m ²]	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,00
$H_{r,inc,2}$ [W/m ²]	62,2	99,5	134,1	166,2	188,3	202,8	217,4	201,1	179,4	140,1	73,9	45,8	1701,8
N_{z1}	31	28	31	30	31	30	31	31	30	31	30	31	365
$P_{max,1000}$ [W]	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0	400,0
A_{pavot} [m ²]	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11	2,11
A_{tot} [m ²]	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22	190,22
ρ_{pv}	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21	0,21
η_i	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97	0,97
η_{inv}	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90	0,90
$E_{elec,j}$ [kWh]	8808,525	12715,374	18978,081	22768,329	26653,402	27768,410	30767,439	28458,992	23332,483	19824,348	10119,972	6478,364	236673,72
E_{el} [kWh]	1265,910	1624,336	2627,928	2973,949	3517,059	3495,232	3955,763	3668,289	2977,441	2671,979	1371,653	833,746	31083,29
E_{emiss} [kgCO ₂]	338,6	434,5	703,0	795,5	940,8	935,0	1058,2	981,3	796,5	714,8	366,9	249,8	8314,78
η_{intake}	22,1%	21,7%	21,3%	20,7%	20,3%	20,0%	19,8%	19,8%	20,3%	20,7%	21,5%	22,1%	



TOTAL ENERGY PRODUCED: 31083.285 [kWh/year]

TOTAL SPECIFIC ENERGY PRODUCED: 8.65 [kWh/sqm.year]

TOTAL CO2 EMISSIONS AVOIDED: 8314.779 [kgCO2/year]

TOTAL CO2 EMISSIONS AVOIDED OF THE AREA: 2.32 [kgCO2/sqm.year]

The total energy produced by photovoltaic panels over a year is obtained with the formula:

Energy Audit Report of the building:
 Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu

$$E_{\text{total}} = \sum E_{\text{li}} = 31083.285 \text{ kWh/year}$$

$$E_{\text{specific}} = 8.68 \text{ KWh/sqm.year}$$

The CO2 emissions avoided by installing the photovoltaic panels are 8.314 tons/year or 2.32 kg/sqm/year.

Also, package 2 provides a heat air-water pump. The calculation considered conventionally a single heat pump that provides the heating and the hot running water preparation. The following table shows for package 2 the heat pump production for heating and hot running water preparation.

Month	Jan	Feb	Mar	Apr	Mai	Jun	Jul	Aug	Sep	Oct	Nov	Dec
$\theta_{\text{gen,ext}} [^{\circ}\text{C}]$	-2,3	-0,3	3,8	9,7	15,2	18,5	20,1	19,2	14,0	9,2	3,6	-1,5
No. of days	15	15	23	15	25	8	5	0	8	20	25	15
$t_{\text{el}} [\text{h}]$	360	360	552	360	600	192	120	0	185	480	600	360
$Q_{\text{gen,dis,out}_1} [\text{kWh}]$	3084,7	3083,1	4723,1	5126,9	5122,7	4916,6	3071,4	0,0	4098,5	4101,9	5135,0	3084,2
$\theta_{\text{gen,dis,out}_1} [^{\circ}\text{C}]$	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0
$Q_{\text{gen,dis,out}_2} [\text{kWh}]$	22264,2	20787,4	27077,3	13922,8	13522,9	3274,6	0,0	0,0	12768,2	18927,8	28882,8	21579,5
$\theta_{\text{gen,dis,out}_2} [^{\circ}\text{C}]$	36,2	35,2	33,1	30,2	27,4	25,8	25,0	25,4	28,0	30,4	33,2	35,8
$\theta_{\text{gen,in}} [^{\circ}\text{C}]$	-2,3	-0,3	3,8	9,7	15,2	18,5	20,1	19,2	14,0	9,2	3,6	-1,5
$\theta_{\text{gen,sto,out}} [^{\circ}\text{C}]$	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0
$E_{\text{H,gen,in}} [\text{kWh}]$	4695,7	4314,6	5610,7	3637,3	4165,1	1900,7	1171,7	0,0	2097,5	4235,0	6149,1	4534,8
$Q_{\text{H,gen,rs,rb}} [\text{kWh}]$	117,4	107,8	140,3	90,9	104,1	47,5	29,3	0,0	52,4	105,9	153,7	113,4
$Q_{\text{H,gen,ren,in}} [\text{kWh}]$	3763,9	4347,5	8306,9	5592,3	13043,0	2852,8	1827,8	0,0	2454,1	6584,6	8944,9	4005,8
$W_{\text{H,gen,aux}} [\text{kWh}]$	234,8	215,7	280,5	181,9	208,3	95,0	58,8	0,0	104,9	211,7	307,5	228,7
$E_{\text{H,gen,bu,in}} [\text{kWh}]$	3,0	3,0	3,0	3,0	3,0	3,0	3,0	0,0	3,0	3,0	3,0	3,0
$Q_{\text{H,gen,out}} [\text{kWh}]$	5260,6	5474,2	9057,2	4814,7	11984,2	0,0	0,0	0,0	403,6	8714,7	9888,2	5346,0
$Q_{\text{W,gen,out}} [\text{kWh}]$	3084,7	3083,1	4723,1	5126,9	5122,7	4753,5	2999,5	0,0	4098,5	4101,9	5135,0	3084,2
$Q_{\text{H,gen,sto,out}} [\text{kWh}]$	210,8	191,1	193,5	171,8	170,0	164,5	163,5	172,7	164,5	178,5	191,2	209,2

Final calculation – heat pump energy performance (PdC)

- Total electricity consumed : 42512.126 [kWh/year]
- Total consumption of the back-up source energy: 33.000 [kWh/year]
- Total heat loss from auxiliary source: 1062.803 [kWh/year]
- Total energy supplied for heating: 60063.468 [kWh/year]
- Total energy amount from renewable sources: 63823.513 [kWh/year]
- Total energy supplied for hot running water: 45313.178 [kWh/year]
- Total auxiliary energy: 2125.606 [kWh/year]

Energy supplied for storage: 2181.010 [kWh/year]

Package 3 is a maximal package that includes all the solutions proposed above (solutions 1-3) for both the envelope elements and the building installations. The calculation for the heat pump was redone similar to the previous package. The following table shows only the final results for the heat pump. It can be seen that the heat pump will take over approximately 85% of the heating load, the rest continuing to operate on the heating plant.

The following table $E_{\text{H,gen,in}}$ shows the electricity consumed in each month from the heat pump.

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no. 1, Sibiu

PdC capacity at maximum load : 14.00 KW

Number of heat pumps : 2 pcs

Auxiliary electric power: 1400 kW

Total PdC system capacity at maximum load: kW

Part of auxiliary electricity consumed: 0.05

Total PdC system capacity at maximum load: 28.00 kW

Minimum value of the partial load: 0.10

Maximum load efficiency: 4.00

Factor mult.cont.sar.min: 0.90

Reference input temperature: 25.00 °C

Time constancy for ON/OFF operating mode:

Reference output temperature: 35.00 °C

Emitter thermal inertia category: 2

Heat pump model: PdC Air-Water (Pn<100 kW)

Auxiliary electrical power for storage: 3.00 kW

Back-up source energy efficiency: 1.00

Mass pump flow: 3.00 m³/h

Recoverable part of stand-by loss: 0.75

Type of refrigeration agent used: R41δa

Part of auxiliary energy recovered as thermal energy: 0.26 Conversion factor: 1725.00 kgCo2/kg

Part of auxiliary energy recovered: 0.50

Loss ratio: 6.00%

Part of electricity to the distribution subsyst: 0.50

Refrigerant capacity: 6.00 kg

Correction factor depending on the aux.comp.temp: 0.00

Month	Jan	Feb	Mar	Apr	Mai	Jun	Iul	Aug	Sep	Oct	Noi	Dec
θ _{gen,ext} [°C]	-2,3	-0,3	3,8	9,7	15,2	18,5	20,1	19,2	14,0	9,2	3,6	-1,5
No.of days	15	15	23	15	25	8	5	0	7	20	25	15
t _{cl} [h]	360	360	552	360	600	192	120	0	160	480	600	360
Q _{gen,dis,out,1} [kWh]	3087,8	3086,4	4728,2	5132,6	5128,4	4917,7	3070,0	0,0	4102,2	4106,6	5139,6	3087,3
θ _{gen,dis,out,1} [°C]	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0
Q _{gen,dis,out,2} [kWh]	7430,7	6562,0	7720,7	2978,5	2417,5	485,4	0,0	0,0	1894,2	4106,8	8796,7	7104,7
θ _{gen,dis,out,2} [°C]	36,2	35,2	33,1	30,2	27,4	25,8	25,0	25,4	26,0	30,4	33,2	35,8
θ _{gen,in} [°C]	-2,3	-0,3	3,8	9,7	15,2	18,5	20,1	19,2	14,0	9,2	3,6	-1,5
θ _{gen,sto,out} [°C]	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0	45,0
E _{H,gen,in} [kWh]	4244,2	3660,3	3998,7	2880,3	2320,9	1900,7	1171,7	0,0	1655,6	2347,2	4512,4	3998,7
Q _{H,gen,stor} [kWh]	106,2	91,3	99,9	87,0	58,0	47,5	29,3	0,0	41,4	58,7	112,8	100,0
Q _{H,gen,ren,in} [kWh]	4212,6	6011,2	8432,2	8430,6	6223,0	2852,8	1827,8	0,0	2191,4	5968,2	9423,9	4560,3
W _{H,gen,aux} [kWh]	212,3	182,6	198,8	134,0	116,0	96,0	88,8	0,0	82,8	117,4	228,8	200,0
E _{H,gen,bu,in} [kWh]	3,0	3,0	99,9	87,0	58,0	3,0	3,0	0,0	3,0	58,7	112,8	3,0
Q _{H,gen,out} [kWh]	6268,0	6486,7	7720,7	2978,6	2417,5	0,0	0,0	0,0	0,0	4106,6	8796,7	5353,7
Q _{W,gen,out} [kWh]	3087,8	3086,4	4728,2	6132,6	6126,4	4763,5	2899,6	0,0	3846,9	4106,6	5139,6	3087,3
Q _{H,gen,sto,out} [kWh]	170,0	168,0	170,0	164,8	170,0	164,5	132,4	173,0	164,5	170,0	164,6	170,0

Final calculation – heat pump energy performance (PdC)

Total electricity consumed : 32481.608 [kWh/year]

Total consumption of the back-up source energy: 414.440 [kWh/year]

Total heat loss from auxiliary source: 812.040 [kWh/year]

Total energy supplied for heating: 42130.826 [kWh/year]

Total energy amount from renewable sources: 55032.317 [kWh/year]

Total energy supplied for hot running water: 45094.837 [kWh/year]

Total auxiliary energy: 1624.080 [kWh/year]

Energy supplied for storage: 1972.257 [kWh/year]

The determination of final energy consumption before and after refurbishment is carried out in accordance with MC001-chapters 3 and 4 following the same steps detailed in the previous chapters.

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

The following table shows the annual consumption of thermal energy, electricity, primary energy and specific primary energy for heating, hot water consumption, ventilation, cooling, lighting followed by energy from renewable sources. The calculations were made for each package separately. The last column shows the consumption reductions of each indicator in the package compared to the unrefurbished building.

Packages		INC	ACC	VENT	R	LIGHTING	Energy from renewable sources	TOTAL	Decrease compared to CNR (%)
CNR	Thermal energy [MWh/year]	181.224	52.348	0	0	0	0	233.572	
	Electricity [MWh/year]	1.856	0.44	55.848	0	33.69	45.917	91.834	
	Primary energy [MWh/year]	216.672	62.347	139.62	0	84.226	45.917	502.865	
	Specific primary energy [MWh/year]	60.52	17.42	39	0	23.53	12.83	140.47	
P1	Thermal energy [MWh/year]	88.951	52.236	0	0	0	0	141.187	39.6
	Electricity [MWh/year]	1.682	0.439	55.848	0	33.69	45.83	91.659	0.2
	Primary energy [MWh/year]	108.277	62.215	139.62	0	84.226	45.83	394.338	21.6
	Specific primary energy [MWh/year]	30.24	17.38	39	0	23.33	12.8	110.15	21.6
P2	Thermal energy [MWh/year]	171.867	47.753	0	0	0	0	219.62	6.0
	Electricity [MWh/year]	48.089	20.081	19.089	0	16.351	63.881	103.61	-12.8
	Primary energy [MWh/year]	239.241	41.634	39.303	0	33.665	63.881	353.843	29.6
	Specific primary energy [MWh/year]	66.83	11.63	10.98	0	9.4	17.84	98.84	29.6
P3	Thermal energy [MWh/year]	45.023	47.607	0	0	0	0	92.63	60.3
	Electricity [MWh/year]	22.568	18.571	19.089	0	16.351	53.714	76.579	16.6
	Primary energy [MWh/year]	48.084	34.842	35.333	0	30.265	53.714	148.524	70.5
	Specific primary energy [MWh/year]	13.43	9.73	9.87	0	8.45	15	41.48	70.5

According to the calculation methodology, the maximum allowable values of the total primary energy consumption for the major refurbishment of the current building is 82.7 kWh/m², year and the CO₂ emissions are 13.1 kg/m².year. It is observed that the works that make the scope of this work (the works in package 3) cause a significant reduction in consumption as a result of the interventions in the envelope but also due to the introduction of renewable energy production sources.

5. Analysis of the economic efficiency of interventions works

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

The second activity carried out during this stage consists into the analysis of the energy effects of applying each solution presented above.

This analysis involved the reassessment of the basic energy indicators of the building in each new option. Mainly, it concerns the annual energy consumption of the building, the primary energy consumption and the CO emissions resulting from applying each measure, and the extent to which this is reduced compared to the current situation.

Observing the energy effects of the various solutions, two solution packages were created, obtained by coupling the solutions presented previously. In calculating the investment cost, only the cost of investments that have a direct influence on the energy efficiency of the building was taken into account.

5.1. Economic calculation premises

The following were assumed and calculated respectively:

The amounts necessary to carry out the investment works are considered to be at the disposal of the investment beneficiary, who does not have to resort to bank loans;

- Economic calculations are carried out in EUR;
- The specific cost of unsubsidized thermal energy is 94 EUR/ MWh;
- The specific cost of electricity is 212 EUR/ MWh;

In this regard, the annual final energy consumption [MWh/year], onsite renewable energy consumption (photovoltaic panels, heat pump), total final energy consumption with payment, non-renewable and renewable primary energy consumption and equivalent CO2 emissions [ton CO2/year] are taken into account. These values were determined for each solution package.

CNR - UNREFURISHED BUILDING													
Solution Package Class	Final energy consumption acc to Mc001					REG onsite energy consumption (E _{REP,CE,PH})		Total final energy consumption with payment		Primary energy consumption acc to Mc001			CO2 equivalent emissions acc to Mc001 (CO ₂ -e/year)
	Heating	HRW	Ventilation	Cooling	Lighting	Electric	Thermal	Electric	Thermal	NREG	REG	Total	
	(MWh/year)					(MWh/year)		(MWh/year)		(MWh/year)			
CNR	189.1	52.8	55.8	0.0	33.7	0.0	0.0	91.8	239.6	456.9	49.9	502.9	79.8
Class	E	E	E	-	C							C	C

CR - REFURISHED BUILDING														
Solution Package Class	Final energy consumption acc to Mc001					REG onsite energy consumption (E _{REP,CE,PH})		Total final energy consumption with payment		Primary energy consumption acc to Mc001			CO2 equivalent emissions acc to Mc001 (CO ₂ -e/year)	PER %
	Heating	HRW	Ventilation	Cooling	Lighting	Electric	Thermal	Electric	Thermal	NREG	REG	Total		
	(MWh/year)					(MWh/year)		(MWh/year)		(MWh/year)				
P1	90.6	52.7	55.8	0.0	33.7	0.0	0.0	91.7	141.2	348.5	49.8	394.3	57.9	11.62
Class	A	E	E	-	C							E	E	
P2	220.0	67.8	19.1	0.0	16.4	24.2	107.6	79.4	112.1	290.0	-69.9	359.8	48.4	37.16
Class	B	E	E	-	A							E	E	
P3	67.6	68.2	19.1	0.0	16.4	31.1	89.2	49.5	3.4	94.8	53.7	148.3	13.6	60.12
Class	A+	A	E	-	A							A+	A+	

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,

In the following table, for each package, the final energy savings, the variation in energy consumption from renewable sources, the total final energy savings charged, the primary energy savings and the CO2 emission reductions compared to the unrefurbished building were calculated.

REFURBISHED VS UNREFURBISHED BUILDING															
Solution / Package	Final energy saving acc. to Mc001					REG- onsite energy consumption variation		Total priced final energy saving		Primary energy saving			CO2 equivalent emissions saving		
	Heating	HRW	Ventilation	Cooling	Lighting	Electric	Thermal	Electric	Thermal	NREG	REG	Total			
	[MWh/yr]					[MWh/yr]		[MWh/yr]		[MWh/yr]			[%]	[tCO ₂ e/yr]	[%]
P1	92,4	0,1	0,0	0,0	0,0	0,0	0,0	0,2	92,4	108,4	0,1	108,5	21,8	21,9	27,4
P2	-36,9	-15,0	36,8	0,0	17,3	24,2	107,8	12,4	121,5	167,0	-18,0	149,0	29,6	31,4	39,4
P3	115,5	-13,4	36,8	0,0	17,3	31,1	89,2	48,3	230,1	382,1	-7,8	354,3	70,5	66,2	83,0

5.2. Economic efficiency indicators used in the economic analysis of the solutions:

The third activity undertaken within this team consists into the economic analysis of the implementation of the proposed individual solutions and the proposed solution packages. This analysis involves the evaluation of:

- the investment costs of the refurbishment options,
- the life span of the refurbishment options,
- the energy savings due to implementing the refurbishment options.

Taking into account the specific cost of thermal energy, the following is determined:

- the investment recovery period for each refurbishment option;
- the percentage reduction in energy consumption;

For a better understanding of the terms presented in this chapter, we will present the definitions in accordance with the Mc001 methodology.

- Energy modernization measure - Intervention on the construction and its related systems, with the aim of reducing the building's energy consumption.
- Lifetime of the modernization solution - The estimated life time for the modernization solution analyzed, for which the considered parameters remain unchanged from the initial stage, at the time of implementing the respective solution.
- Investment payback period - The duration of the investment recovery through the savings achieved as a result of the reduction in energy consumption due to applying the energy refurbishment/modernization measures.
- Net present value - The projection at time "0" of all the costs involved in the application of a measure/solution for the energy modernization of the building, depending on the depreciation rate of the currency considered - in the form of the average annual depreciation and the average annual rate of increase in the energy cost.

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1, Global updated cost CG - Sum of the updated initial investment costs, annual operating costs and replacement costs as well as disposal costs if necessary, over a fixed calculation period (20 years for commercial buildings, 50 years for residential buildings, 30 years for other building categories)

- Operating cost CO_{run} - The operating cost that includes the maintenance cost, the operational cost and the energy cost for the time step considered.

- CO_{ma} Maintenance costs - The cost of measures related to the conservation and restoration of the desired quality for the building, construction element or system. This includes the annual costs for inspection, cleaning, interventions, repairs as part of preventive maintenance, the cost of consumable materials.

- CO_{en} Energy costs - The cost of energy, including fixed items and tariffs and taxes applicable at national level.

- CO_{rpl} - Replacement cost of the component or system Replacement investment for a component of the building, based on the estimated economic life cycle during the calculation period.

- * CO_{CO2} Greenhouse gas emissions cost - Monetary value of the environmental damage due to general CO_2 emissions from energy use in buildings (20/35/50 Eur/t CO_2 from 2020/2025/2030). CO_2 emissions reflect the effects of all greenhouse gases weighted according to their global warming potential, expressed in kilograms of CO_2 equivalent over a period of 100 years.

- RAT_{dev} Price change rate - Changes in the prices of energy, products, building systems, services, labour, maintenance and other costs over time. This rate may differ from the inflation rate.

The economic analysis of energy modernization measures for the current buildings leads to the choice of economically efficient measures, through the prism of economic indicators, among which the fundamental indicator is the updated global cost (CG).

The effective implementation of an energy modernization project also involves the analysis of the possible financing of the project, from the point of view of the possible financing scheme to be applied and from the point of view of the affordability of the project beneficiary.

The Updated Global Cost (CG) is given by the relationship:

$$CG = CO_{init} + \sum_{i=1}^{rc} \left[\sum_{j=1}^{n} \left(CO_{a(i)}(j) * (1 + RAT_{xx(i)}(j)) + CO_{CO2(i)}(j) + CO_{fin(TLS)}(j) - Val_{ft}(j) \right) \right]$$

where:

CG total investment cost in year "0" [Euro];

CO_{init} initial investment cost;

$CO_{a(i)}(j)$ the annual cost of renovation component or measure j for year i;

$RAT_{xx(i)}$ price change rate for year I of renovation component or measure j

Energy Audit Report of the building:

Highschoolbuilding within the Technical Energy College from Electricienilor street, no. 1,
 $C_{CO_2(j)}$ - cost of CO_2 emissions for measure j in year i

$CO_{fin.}(TLS)(j)$ - final cost for decommissioning and disposal in the last year of the TLS life cycle of component j or of the building (related to the first year T_0);

$Val_{fct}(j)$ - residual value of component j in year TC at the end of the calculation period (related to the first year T_0);

$$\Delta VNA_{(m)} = C_{(m)} - \sum \Delta C_{E_k} \cdot X_k$$

VNA related to additional investment due to the applying the energy modernization projects and energy savings resulting from applying the aforementioned projects:

where:

$C_{(m)}$ - the investment cost related to the energy modernization project, at the level of year “0”, [Euro];

ΔC_{E-} - reduction in annual operating costs following the implementation of energy modernization projects at the level of the reference year, [Euro/year]:

$$\Delta C_{E_k} = c_k \cdot \Delta E_k$$

where:

ΔE_k - represents the estimated annual energy saving k , obtained by implementing an energy modernization measure, [kWh/year],

c_k - represents the current cost of the energy unit k , [Euro / kWh]

The following table shows the total investment cost and the other parameters of the economic calculation for the unrefurbished building (CRN) and for therefurbished building, respectively for each package (CRP), the total investment cost and the other parameters of the economic calculation.

Dimension	MU	CNR	CR-P1	CR-P2	CR•P3
Floor reference area	sqm	3580			
Investment initial total cost	[EUR VAT included]	0,0	580910.0	228646.0	809556.0
Investment specific cost	EUR.sqm VAT included	0.0	162.3	63.9	226.1
Maintainance annual cost	EUR VAT included/year	8702.4	2450.0	3455.0	4191.0
Average annual rate maintainance cost	%	6.0			
Annual operating costs	EUR VAT included/year	0,0	0,0	0,0	0,0
Average annual rate operating costs	(%)	3.0			
Annual final thermal energy consumption	MWh/year	233.6	141.2	112.1	3.4
Thermal energy unit cost	EUR VAT incl./MWh	94.0	94.0	94.0	94.0
Annual thermal energycost	EUR VAT included/year	21955.8	13721.6	10533.9	322.6
Annualaverage thermal energy increase rate	%	5,0			
Annual final electricity consumption	MWh/year	91.8	91.7	79.4	45.5
Electricityunit cost	EUR VAT incl./MWh	212,0	212,0	212,0	212,0
Annual electricity cost	EUR VAT included/year	19468.8	19431.7	16840.0	9645.2
Annual average electricity increaserate	%	5,0			
Periodic replacement costs	EUR VAT included/year	61346.9	61346.9	82312.6	88447.2
Annual average replacement costs increase rate	%	3,0			
Decommissioning costs	EUR VAT included)	0,0	0,0	0,0	0,0
CO2 equivalent emissions/year	tCO2e/year	79.8	57.9	48.4	13.6
Specific CO2 cost	EUR/ tCO2e	20.0			
Annual CO2 equivalent emissions costs [2025]	EUR VAT included/year	1595.4	1157.8	967.0	271.4
Package life cycle	years	-	30	20	20
Calculation period/Global cost calculation period	years	30			
Residual value	EUR VAT included	0,0	0,0	30624.1	32905.5
Costs update rate(interest rate)	%	3.0			

The condition for an investment in the energy modernization solution to be efficient is the following:

$$CG < 0$$

In this economic analysis of the refurbishment options, the following assumptions and values were taken into account:

- the beneficiary bears the cost without bank credit;
- economic calculations are made in euros;
- annual rate of increase in maintenance costs 6%;
- annual rate of increase in the cost of heat and electricity 5%;
- annual rate of increase in replacement costs 5%;
- annual rate of depreciation of the currency (Euro) 3%;
- in each package it is considered that the thermal and electrical systems including photovoltaic and solar panels are replaced after 20 years
- the calculation of the investment cost does not include the interior finishes of the building, the repair of the cold water supply system and the sewage system, the organization of construction site, design services, other related expenses (management, consultancy, etc.) or costs for the building to comply with other national requirements (ISU, DSP, etc.)

The following table shows the energy costs consumed for the unrefurbished building and for each package

Dimension	UM	CNR	CR-PI	CR-P2	CR-P3
Annual final thermal energy consumption	[MWh/year]	233.572	141.187	112.063	3.432
Thermal energy unit cost	[Eur VAT included/MWh]	94			
Annual thermal energy cost	EUR VAT included/year	21955.768	13721.578	10533.922	322.608
Annual final electricity consumption	[MWh/year]	91.834	91.659	79.434	45.946
Electricity unit cost	Eur VAT included/MWh	212			
Electricity annual cost	EUR VAT included/year	19468.808	19431.708	16840.008	9645.152

The following tables show the savings calculation for the packages considered compared to the unrefurbished building, taking into account the maintenance costs, electricity and thermal energy, CO₂, replacement costs and residual value.

CNR – UNREFURBISHED BUILDING

0	1	2	3	4	5	6	7	8	9
YEAR	Annual maintenance cost CNR	Annual Updated thermal operating cost CNR	Updated thermal energy cost CNR	Updated electricity cost CNR	Periodic replacement costs CNR	Residual value replacement costs CNR	Decommissioning costs CNR	Annual CO2 equivalent emissions costs CNR	Updated operating costs CNR

2025	0	8702,4	0,0	21955,8	19468,8	61346,9	0,0	0,0	1595,4	51722,4
2026	1	8955,9	0,0	22382,1	19846,8	0,0	0,0	0,0	2792,0	53976,8
2027	2	9216,7	0,0	22816,7	20232,2	0,0	0,0	0,0	2792,0	55057,6
2028	3	9485,2	0,0	23259,7	20625,1	0,0	0,0	0,0	2792,0	56161,9
2029	4	9761,4	0,0	23711,4	21025,6	0,0	0,0	0,0	2792,0	57290,3
2030	5	10045,7	0,0	24171,8	21433,8	0,0	0,0	0,0	2792,0	58443,3
2031	6	10338,3	0,0	24641,2	21850,0	0,0	0,0	0,0	3988,5	60818,0
2032	7	10639,5	0,0	25119,6	22274,3	0,0	0,0	0,0	3988,5	62021,9
2033	8	10949,3	0,0	25607,4	22706,8	0,0	0,0	0,0	3988,5	63252,0
2034	9	11268,3	0,0	26104,6	23147,7	0,0	0,0	0,0	3988,5	64509,1
2035	10	11596,5	0,0	26611,5	23597,2	0,0	0,0	0,0	3988,5	65793,6
2036	11	11934,2	0,0	27128,2	24055,4	0,0	0,0	0,0	3988,5	67106,3
2037	12	12281,8	0,0	27655,0	24522,5	0,0	0,0	0,0	3988,5	68447,8
2038	13	12639,5	0,0	28192,0	24998,6	0,0	0,0	0,0	3988,5	69818,7
2039	14	13007,7	0,0	28739,4	25484,0	0,0	0,0	0,0	3988,5	71219,6
2040	15	13386,5	0,0	29297,4	25978,9	0,0	0,0	0,0	3988,5	72651,4
2041	16	13776,4	0,0	29866,3	26483,3	0,0	0,0	0,0	3988,5	74114,6
2042	17	14177,7	0,0	30446,3	26997,6	0,0	0,0	0,0	3988,5	75610,0
2043	18	14590,6	0,0	31037,4	27521,8	0,0	0,0	0,0	3988,5	77138,4
2044	19	15015,6	0,0	31640,1	28056,2	0,0	0,0	0,0	3988,5	78700,4
2045	20	15453,0	0,0	32254,5	28601,0	0,0	0,0	0,0	3988,5	80296,9
2046	21	15903,1	0,0	32880,8	29156,3	0,0	0,0	0,0	3988,5	81928,7
2047	22	16366,2	0,0	33519,2	29722,5	0,0	0,0	0,0	3988,5	83596,5
2048	23	16842,9	0,0	34170,1	30299,6	0,0	0,0	0,0	3988,5	85301,2
2049	24	17333,5	0,0	34833,6	30888,0	0,0	0,0	0,0	3988,5	87043,6
2050	25	17838,4	0,0	35510,0	31487,7	0,0	0,0	0,0	3988,5	88824,6
2051	26	18357,9	0,0	36199,5	32099,1	0,0	0,0	0,0	3988,5	90645,1
2052	27	18892,6	0,0	36902,4	32722,4	0,0	0,0	0,0	3988,5	92505,9
2053	28	19442,9	0,0	37619,0	33357,8	0,0	0,0	0,0	3988,5	94408,2
2054	29	20009,2	0,0	38349,4	34005,5	0,0	0,0	0,0	3988,5	96352,6
2055	30	20592,0	0,0	39094,1	34665,8	0,0	0,0	0,0	3988,5	98340,4

CR-P1 (REFURBISHED BUILDING - PACKAGE 3)

YEAR	Annual maintenance cost CR	Annual operating cost CR	Updated thermal energycost CR	Updated electricitycost CR	Periodic replacement costsCR	Residual value replacement costs CR	Decommissioning costsCR	AnnualCO2 equivalent emissions costs CR	Updated operating costs CR	CASH FLOW	VNA	
2025	0	4191,0	0,0	322,6	9645,2	88447,2	32906,5	0,0	271,4	14430	-	809556
2026	1	4313,1	0,0	328,9	9832,4	0,0	0,0	0,0	475,0	14949	-39027	770529
2027	2	4438,7	0,0	335,3	10023,4	0,0	0,0	0,0	475,0	15272	-39785	730743
2028	3	4568,0	0,0	341,8	10218,0	0,0	0,0	0,0	475,0	15603	-40559	690184
2029	4	4701,0	0,0	348,4	10416,4	0,0	0,0	0,0	475,0	15941	-41350	648834
2030	5	4837,9	0,0	355,2	10618,7	0,0	0,0	0,0	475,0	16287	-42157	606678
2031	6	4978,9	0,0	362,1	10824,8	0,0	0,0	0,0	678,5	16844	-43974	562704
2032	7	5123,9	0,0	369,1	11035,0	0,0	0,0	0,0	678,5	17206	-44815	517889
2033	8	5273,1	0,0	376,3	11249,3	0,0	0,0	0,0	678,5	17577	-45675	472214
2034	9	5426,7	0,0	383,6	11467,7	0,0	0,0	0,0	678,5	17957	-46553	425661
2035	10	5584,8	0,0	391,0	11690,4	0,0	0,0	0,0	678,5	18345	-47449	378212
2036	11	5747,4	0,0	398,6	11917,4	0,0	0,0	0,0	678,5	18742	-48364	329848
2037	12	5914,8	0,0	406,3	12148,8	0,0	0,0	0,0	678,5	19148	-49299	280549
2038	13	6087,1	0,0	414,2	12384,7	0,0	0,0	0,0	678,5	19565	-50254	230294
2039	14	6264,4	0,0	422,3	12625,2	0,0	0,0	0,0	678,5	19990	-51229	179065
2040	15	6446,8	0,0	430,5	12870,3	0,0	0,0	0,0	678,5	20426	-52225	126840
2041	16	6634,6	0,0	438,8	13120,3	0,0	0,0	0,0	678,5	20872	-53242	73598
2042	17	6827,9	0,0	447,4	13375,0	0,0	0,0	0,0	678,5	21329	-54281	19316
2043	18	7026,7	0,0	456,1	13634,7	0,0	0,0	0,0	678,5	21796	-55342	-36026
2044	19	7231,4	0,0	464,9	13899,5	0,0	0,0	0,0	678,5	22274	-56426	-92452
2045	20	7442,0	0,0	473,9	14169,4	0,0	0,0	0,0	678,5	22764	-57533	-149985
2046	21	7658,8	0,0	483,1	14444,5	88447,2	0,0	0,0	678,5	111712	29783	-120202
2047	22	7881,8	0,0	492,5	14725,0	0,0	0,0	0,0	678,5	23778	-59819	-180020
2048	23	8111,4	0,0	502,1	15010,9	0,0	0,0	0,0	678,5	24303	-60998	-241019
2049	24	8347,7	0,0	511,8	15302,4	0,0	0,0	0,0	678,5	24840	-62203	-303222
2050	25	8590,8	0,0	521,8	15599,5	0,0	0,0	0,0	678,5	25391	-63434	-366656
2051	26	8841,0	0,0	531,9	15902,4	0,0	0,0	0,0	678,5	25954	-64691	-431347
2052	27	9098,5	0,0	542,2	16211,2	0,0	0,0	0,0	678,5	26530	-65975	-497323

Energy Audit Report of the building:

Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,

The calculation was redone for each package, resulting into the following recovery times for each of the packages::

Renovation measures package	Decreased duration of „investment recovery”	Global cost [Eur VAT included] (20 years)	Package hierarchy f(CG)
CNR	-	2231375.4	-
CR-P1	27	2121874.9	III
CR-P2	10	1637868.1	I
CR-P3	18	1495234.7	11

C. Conclusions

Following the energy and economic analyses presented in the calculation notes and the interpretation of the results obtained, the following conclusions were reached.

1. The energy audit was carried out for the Highschool building of the Technical Energy College located within the premises of the Technical Energy College located in the municipality of Sibiu. It was carried out taking into account the in-depth thermal refurbishment works expected by the beneficiary.

2. The building envelope in the current situation does not comply with the minimum strengths provided by the regulations in force.

3. Based on the calculations of specific consumption and the penalties granted in the energy rating, the certified building is classified into energy class D (overall) with a specific primary energy consumption of 239.0 kWh/m²/year, compared to the reference building which is classified into energy class B with a specific primary energy consumption of 82.70 kWh/m²/year. Regarding the level of equivalent CO₂ emissions, the current building falls into class D with 42.1 kgCO₂/m²/year, compared to the reference building which is classified into class B with 13.10 kgCO₂/m²/year-

4. The following solutions, developed in detail in chapter 4.1, are proposed for the building investigated:

- Solution 1.

- Thermal insulation of the exterior walls with a layer of expanded polystyrene or mineral wool with a thickness of 15 cm and a thermal conductivity $\gamma < 0.038$ W/mK

- Thermal insulation of the floor above the ground floor with sheep wool-based insulation material with a thickness of 25 cm and a minimum thermal strength of $\gamma < 0.038$ W/mK, over which a wooden floor will be built.

- Thermal insulation of the floor over the technical channel with a layer of expanded polystyrene or mineral wool with a thickness of 10 cm and a minimum thermal resistance of $\gamma < 0.038$ W/mK, over which a wooden floor will be built

- Solution 2.

- Replacing the exterior windows with efficient carpentry which thermal strength is at least $R_{min} = 0.83$ m² K / W.

- Replacing the exterior doors with efficient carpentry which thermal strength is at least $R_{min} = 0.77$ m² K / W.

Energy Audit Report of the building:

Highschool building within the Technical Energy College from Electricienilor street, no. 1, Sibiu county

- Solution 3. Modifying the building's installations as follows:

- o Introducing a new heat production system composed of heat pumps and condensing gas boilers that will serve three building units (high school, workshop and Highschool building). Gas-fired central heating will take over any peaks in consumption.

- o A photovoltaic panel system with a capacity of 18 kWh will be installed on the high school's roof on the SE or SW orientations

- o A heat recovery fan system with an average thermal transfer efficiency of 75% will be installed.

- o The lighting fixtures and lighting sources will be replaced with LEDs. Presence sensors will be used for circulation spaces.

The energy and economic analyses presented in the calculation notes in this document highlight the qualities of the different refurbishment packages. Thus:

1. The P1 package is a package that includes solutions S1-S2 and is recovered in 27 years. The package of measures leads to an increase in the thermal strengths of the opaque envelope up to the minimum strengths requested by the codes in force. In terms of primary energy consumption and CO₂ emissions, the package does not fall within the minimum values provided by the methodology. With this package of measures, the annual primary energy saving is 21.6% (from 502.865 MWh/year to 394.34 MWh/year) and CO₂ emissions are reduced by 27.4% (from 79.8 tons/year to 57.9 tons/year). It is noted that the recovery period is long but falls within the construction's lifespan of 30 years.

2. Package P2 is a package that includes solution S3 and is recovered in 8 years. The package of measures leads to increased efficiency of systems and the use of renewable energy sources. This package does not fall within the minimum values provided by the methodology in terms of primary energy consumption and CO₂ emissions. With this package of measures, the annual primary energy saving is 29.6% (from 502.865 MWh/year to 353.843 MWh/year) and CO₂ emissions are reduced by 39.4% (from 79.8 tons/year to 48.4 tons/year)

3. Package P3 is a maximum package in terms of investment that includes solutions S1-S3 and is recovered in 18 years. The package of measures leads to an increase in both the thermal strength of the envelope to the minimum strengths requested by the codes in force and a reduction in consumption within the minimum values provided by the methodology. With this package of measures, the annual primary energy saving is 70.5% (from 502.865 MWh/year to 148.524 MWh/year) and CO₂ emissions are reduced by 83% (from 79.8 tons/year to 13.6 tons/year). The results obtained following the application of the package of measures are presented in tabular form below.

Energy Audit Report of the building:

Highschool building within the Technical Energy College from Electricienilor street, no. 1,
Fulfillment indicator for package P3
 Indicator value before renovation
 Indicator value after renovation
 Reduction (%)

Total final thermal energy consumption (MWh/year)	233.572	92.63	60.3
Total final electricity consumption(MWh/year)	91.834	76.579	16.6
Total primary energy consumption(MWh/year)	502.865	148.524	70.5
Total specific primary energy consumption (kWh/m2year)	140.47	41.478	70.5
Energyclass	C	A+	
Amount of CO2 equivalent emissions (kg CO2/m2,year)	22.3	3.8	83.0
Environmental class	C	A+	
Final thermal payment energy[MWh/year)	233.57	3.4	98.5
Final electricity payment [MWh/year]	91.83	45.5	50.5

4. Applying the package of measures proposed is economically feasible, amortizing the investment value over a period of 18 years. The value is lower than the shelf life of the package, which is estimated at 20 years, and causes significant energy reductions. The long recovery time is caused by the high intervention costs at the high school envelope level. However, considering the significant CO2 reductions of 83%, package 3 is recommended.

5. The results of the building's energy audit represent the calculation basis for the feasibility study that establishes the appropriate refurbishment option for the beneficiary of the building under analysis. Once the refurbishment option has been identified, it will proceed to its design and then to the execution of the refurbishment works according to the refurbishment project.

6. Based on the technical and economic analyses carried out, it is recommended to implement the P3 package, as it represents the efficient and compliant solution with the regulations in force. Following the application of thermal refurbishment measures, the building becomes energy efficient, falling into energy performance class A+. The financial evaluation included in the energy audit cannot be used as documentation to substantiate the request for financing or crediting the proposed works, however, based on the energy audit, it is easy to proceed to the preparation of the feasibility study, for the approval of the economic indicators of the investment.

Energy auditor for buildings

eng. Cruciat Radu

Illegible signature, Official stamp

Drafted by

Energy auditor for buildings

eng. Pricopie Andrei Gheorghe

Illegible signature, Official stamp

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no. 1,

D. Recommendations for the owners

- Informing the responsible technical staff about the expected energysavings;
- Correct understanding of how the building and its installations should operate at a general and detailed level
- Designating a representative to monitor the execution of the thermal refurbishment works;
- Establishing an energy saving policy in operation;
- Analyzing energy bills and energy supply contracts and modifying them if necessary. It is recommended to choose suppliers that produce energy from renewable sources.
- Hiring an energy manager;
- Adapting and adjusting the heating plants ofthe spaces to the reduced heat requirement as a result of the execution of the intervention works;
- Washing the heating installation, including the radiators, at regular intervals of 3 years;
- Correct thermo-hydraulic balancing of the heating elements;
- Checking and changing batteries that are not perfectly sealed;
- Replacing classic light bulbs withenergy-efficient ones;
- Maintaining proper ventilation of occupied spaces. The ventilation system with heat recoverywill be maintained in working order;
- Periodic inspections of the own central heating systems and their adjustment according to the manufacturers' instructions will be respected. Gas detectors will be installed by the owners.

E. Bibliography

The preparation of the energy audit report of the building was carried out in accordance with the provisions of the new Methodology Mc 001/2022, regarding the calculation ofenergy consumption of buildings.

Other related documents are:

- Normative regarding the thermotechnical calculation of building construction elements. Indicative: C107/2005, approved by the Order of Transport, Construction and Tourism no. 2055/29.11.2005, as amended and completed;
 - Normative for the design, execution and operation of central heating installations, indicative 113-2015, approved by Order of the Minister of Regional Development and Public Administration no. 845/12.10.2015
 - Normative for the design, execution and operation of ventilation and air conditioning installations, indicative 15-2010, approved by Order of the Minister of Regional Development and Tourism no. 1.659/22.06.2011
 - Normative for the design and execution of sanitary installations, indicative I9-2015, approved by Order of the Minister of Regional Development and Public Administration no. 818/06.10.2015
-

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.1, Sibiu county

- Regulations for the design, execution and operation of electrical installations related to buildings, reference I7-2011, approved by Order of the Minister of Regional Development and Tourism no. 2,741/01.10.2011
 - Framework solutions for the thermo-hygro-energetic refurbishment of the envelope of existing residential buildings, reference SC 007-2013, approved by Order of the Minister of Regional Development and Public Administration no. 2,280/05.07.2013.
 - Guide for the design and execution of thermal refurbishment works of apartment buildings, reference GP 123-2013, approved by Order of the Minister of Regional Development and Public Administration no. 2,211/26.06.2013, as amended and completed.
 - Law no. 372/2005 on the energy performance of buildings, republished,
 - Law no. 10/1995 on quality in construction, republished, as amended and completed
 - Law no. 50/1991 on the authorization of construction works, republished, as amended and completed
-

F. ENERGY ANALYSIS SHEET

A. GENERAL DATA

Building layout plan



Building: Highschool building

Address: Electricienilor street no.1, Sibiu county

Owner: Sibiu City Hall

Building category:

educational establishment (nurseries, kindergardens, schools, highschools, universities)

Climate area where the building is located: III

Wind area where the building is located: IV

Wind exposure level: sheltered

Height regime of the building: ground floor

Construction structure: double strength structure made of reinforced concrete frames and load-bearing masonry

Documents related to the construction and its systems:

architecture survey for each type of representative level

construction representative sections

Building technical basement condition: flooded/floodable basement (water discharge may be due to the exterior sewerage)

B. Features of the living/heated space

Built area (sqm): 1389

Built unfolded area (sqm): 3835

Reference area of the heated space floor (sqm): 3580

Reference volume of the heated space (m³): 12678

Reference area of the cooled space floor (sqm), as appropriate: -

Free average height of one level (m): 2.8 and 3.5

Occupation level of the heated space [no. of operating hrs of the heating system]: 10h/210 days

Ratio between the area of the closed balconies facade and the total area of the facade provided with balconies/loggia: -

Average depth of the groundwater (m): -

C. BUILDING CONSTRUCTIVE STRUCTURE IDENTIFICATION

Dull exterior walls

Exterior wall – masonry

No. crt.	Material	γ [W/mK]	δ [m]	a	R [m ² K/W]
1	Lime mortar plaster	0.87	0.02	1.1	0.021
2	Solid brick masonry	0.8	0.25	1.15	0.290
3	Cement mortar plaster	0.93	0.03	1.1	0.029
$\delta_i=8$ $\delta_e=24$			R0	=	0.507

Exterior walls condition: condensation stains

Finishings condition: partially fallen plaster

Type and colour of the finishing materials:

- type: plaster

- colour: grey

Dividing joints for building sections: Not applicable

Walls to annex areas (staircase, dumpsters): Not applicable

Ground slab:

No. crt	Material	k [W/mK]	δ [m]	a	R [m ² K/W]
1	Sandstone and quartzite	2.03	0.01	1.03	0.005
2	Plain concrete	1.16	0.05	1.03	0.042
3	Reinforced concrete slab	1.62	0.1	1.05	0.059
4	Gravel fill	0.7	0.1	1	0.143
5	Top soil	1.16	0.15	1	0.129
$\delta_i = 6$ $\delta_e = 12$			R0	=	0.545

Total area of the ground slab [sqm]: 972.1

Terrace/Roof

Type of terrace/roof: truss type roof

Terrace/roof condition: dry

Last repair of the terrace/roof: more than 5 years ago

Finishing materials: corrugated sheet

No. Crt.	Material	λ [W/mK]	δ [m]	a	R [m ² K/W]	
1	Corrugated sheet	0.8	0.01	1.05	0.012	
2	Roof boarding	0.17	0.025	1.1	0.134	
				R0	=	0,313

$\delta_i=8$

$\delta_e=24$

Total roof area [sqm]: 1652

Floor under the attic:

No. Crt.	Material	λ [W/mK]	δ [m]	a	R [m ² K/W]	
1	Reinforced concrete slab	1.62	0.14	1.1	0.079	
2	Cement mortar plaster	0.87	0.02	1.03	0.022	
3	Ash and slag	0.290	0.1	1.1	0.313	
					=	0.623

Total area of the floor under the attic [sqm]: 1145

Floor under the technical channel:

No. Crt.	Material	λ [W/mK]	δ [m]	a	R [m ² K/W]	
1	Reinforced concrete slab	1.62	0.1	1.05	0.059	
2	Cement mortar plaster	1.16	0.05	1.03	0.042	
3	Ash and slag	2.03	0.01	1.03	0.005	
					=	0.357

Total area of the floor under the technical channel [sqm]: 324.8

Energy Audit Report of the building:
 Highschool building within the Technical Energy College from Electricienilor street,
 no. 1, Sibiu

Floor under the thermal plant:

No. Crt.	Material	λ [W/mK]	δ [m]	a	R [m ² ·K/W]
1	Limestone	2.09	0.01	1.03	0.005
2.	Simple concrete	1.16	0.05	1.03	0.042
3	Reinforced concrete slab	1.62	0.15	1.05	0.088
4	Cement mortar	0.93	0.0	1.03	0.021
$\delta_i=8$ $\delta_e=24$				=	0.323

Total area of the floor under the thermal plant [sqm]: 151.9

Exterior windows/doors

Carpentry condition: good

EW/ ED	Description	Area [sqm]	Type of carpentry	Sealing grade	Shutter (i / e)
EW	Windows R=0.43	1094.2	PVC carpentry insulated glass	With outdated sealing that is no longer flexible	No
ED	Doors R=0.37	42.5	PVC carpentry insulated glass	With outdated sealing that is no longer flexible	No

Other construction elements: Not applicable

Mobile construction elements from joint spaces: Not applicable

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.1 Sibiu county

D. INTERIOR HEATING SYSTEM

Does the heating system exist: Yes

Need for calculation heating [W]: 127581

Energy sourcefor heating thespaces: own source, gas fuel

Type of heating source: heating with static bodies

Data regarding the interior heating system with static bodies:

Type of thermal heating: lower

Connection tothe centralized heating source: single connection

Thermal energy meter: does not exist

Thermal and hydraulic adjustment items: on the distribution network, on columns, on the static bodies

The static bodies arenot equipped with adjustment fittings or at least half of the current adjustment fittings are not operating

Distribution network located in unheated spaces: - length: 326; - nominal diameter: 88.9; thermal insulation: yes

Interior heating systemcondition in terms of deposits: the static bodies havebeen dismantled and washed/cleaned fully more than three years ago

Separation and drainage fittings of the heating pipes: The hitting pipes areprovided with separation and drainage fittings, operational

Heating system vessels/ventilation fittings: Thereare manual ventilation valves

Are there heat cost allocators installed on the heating systems? No

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.1 Sibiu county

Type of heating body/Type of heating system	Number of heating bodies [pcs.]		
	Number of static bodies[pcs.]		
	In the living area	In the common area	Total
steel	175		175

Heating source – own thermal system

Nominal power: 2x250kW

Are there ISCIR documents: YES

Regulation/automation system and regulation equipments: NO

Are there invoices for the last 5 years that can be examined: YES

E. DATA REGARDING THE HOT RUNNING WATER

Is there a system for preparing the hot running water: Yes

Energy source for preparing the hot water of the spaces: Own source – gas thermal system

Cool water/hot water consumption points:

basins: 19

washers: 0

bidets: 0

urinals: 9

showers: 0

bath: 0

WC : 25

dishwasher: 0

washing machine: 0

Fittings condition: there are small liquid losses

Connection to the centralized heating system: single connection

Recirculation pipe: does not exist

Debit metres of the consumption points: do not exist

ADDITIONAL INFORMATION

Are there any invoices for hot running water for the last 5 years that can be examined: NO

Cool water temperature in the area: 10°C

Energy Audit Report of the building:

Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.1 Sibiu county

Hot water distribution network located in unheated spaces:

Length : 94 m

Thermal insulation: yes

There is an insulation, but it is wet

F. DATA REGARDING THE VENTILATION/ AIR CONDITIONING SYSTEM

Data regarding the air conditioning system

Is there a ventilation and air conditioning system: NO

Data regarding the ventilation system

Type of ventilation: natural

G. DATA REGARDING THE LIGHTING SYSTEM

Type of lighting fixtures: fluorescent

Lighting system control: no automatic detection of the users' presence

Lighting fixtures condition: good

Electrical conductors condition: good

Illegible signature, Official stamp

Energy Audit Report of the building:
Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu

G. PhotoAnnex



Photo 1 – Entrance from Electricienilor street



Photo 2 – SE side entrance



Photo 3 – Thermal plant



Photo 4 & 5 – Photo of the thermal plant, boiler and distribution network

Energy Audit Report of the building:
Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu



Photo 6 – Classroom



Photo 7 - Classroom



Photo 8 – Hall



Photo 9 - Wooden truss

Energy Audit Report of the building:
Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu



Photo 10 - Exterior plaster and base degradations



Photo 11 – Lighting system

H. Other annexes

- Copy of Energy Auditor's badge
- Construction Survey
- Energy Certificate for the current building
- Energy Certificate Annexes

MINISTRY OF REGIONAL DEVELOPMENT, PUBLIC ADMINISTRATION AND EUROPEAN
FUNDS

Mr. PRICOPIE GH. GHEORGHE-ANDREI
Personal identification number: 1850607460121
Job: Engineer
ENERGY AUDITOR FOR BUILDINGS
Professional degree: I
Specialization: CONSTRUCTIONS AND INSTALLATIONS
Date of issue: 08.02.2017

General manager
Illegible signature, Official stamp
Holder's signature - Illegible signature
This badge is valid only accompanied by the attestation
certificate of the energy auditor for buildings
Series SSA number 02249


This badge will be endorsed by the issuing entity from 5 to 5 years from the date of issue
Valid until: 08.02.2022
Validityextension until: 08.02.2027

Mr. CRUCIAT I.RADU-IULIU
Personal identification number: 1850707324784
Job: Engineer
ENERGY AUDITOR FOR BUILDINGS
Professional degree: I
Specialization: CONSTRUCTIONS AND INSTALLATIONS
Date of issue: 08.02.2017

General manager
Illegible signature, Official stamp
Holder's signature - Illegible signature
This badge is valid only accompanied by the attestation
certificate of the energy auditor for buildings
Series SSA number 02208

This badge will be endorsed by the issuing entity from 5 to 5 years from the date of issue
Valid until: 08.02.2022
Validityextension until: 08.02.2027


Energy Audit Report of the building:
Highschoolbuilding withinthe TechnicalEnergyCollege fromElectricienilor street, no. 1,
Sibiu



Groundfloor survey




Energy Audit Report of the building:
Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu




First floor survey

Energy Audit Report of the building:
Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu




Second floor survey


Energy Audit Report of the building:
Highschoolbuilding within the TechnicalEnergyCollege fromElectricienilor street, no.
1, Sibiu



Section



Roof truss survey



Main entrance



Rear entrance



Left side entrance



Right side entrance

RECOMMENDATIONS FOR INCREASING THE ENERGY PERFORMANCE

ANNEX 1 to the Energy Performance Certificate no. 000131/ 550311

for the BUILDING/BUILDING BLOCK/APARTMENT from Siblu, str. Electricienilor no. 1, Sibiu County

1. Solutions recommended for the envelope of the building/building block/apartment

Increasing the thermal strength of the external walls above the minimum value provided by the technical regulations in force, by external thermal insulation

Increasing the thermal strength of the roof (floor under the attic), if any, above the minimum value provided by the technical regulations in force, by external thermal insulation

Replacing the current exterior joinery with energy-efficient joinery.

Assembling on the exterior carpentry or on the exterior walls of the hygroadjustable ventilation grids in order to avoid the increase in the interior moisture and providing the quality of the interior air

Installing devices to shade the facades or protect against solar radiation during the winter.

2. Solutions recommended for installations related to the building/building block/apartment.

Replacing the used pipes for the heating agent and possibly insulating them (same for the columns).

Replacing the used pipes for hot water distribution for heating and possibly insulating them (same for the columns).

Installation of thermostatic valves on the heating elements

Installation of automatic balancing valves at the base of the heating/cooling columns

Ensuring the quality of the indoor air through organized natural ventilation, mechanical ventilation or hybrid ventilation

Use of sanitary fittings with reduced total hot water consumption (use of economic diffusers at the consumption points)

Replacement of seals and repair of defective hot water fittings, installed on sanitary objects.

Provision of a minimum automation/regulation system if it does not exist, for heating/cooling/ventilation

Changing the equipments from the thermal plant, if any, and if the equipments are worn and torn, with modern and energetically efficient equipments

Adjustment/cleaning of the equipment in the heating/air conditioning system, if it exists, and the equipment operates inefficiently

Installation of lighting fixtures with economical sources instead of the existing, inefficient ones

Installation of presence sensors for automatic activation of the lighting system

Use of renewable energy sources to increase the environmental performance of buildings

Use of thermal energy recovery equipment (air-to-air heat exchangers, water heaters, etc.)

Periodic cleaning of the chimneys and flues for the exhaust of combustion gases, if applicable

3. Related measures (corresponding to the energy calculation stages) for increasing the energy performance of the certified building:

A - General organizational measures

Informing building users (owners/tenants) about the advantages of energy savings and pollution reduction

Encouraging occupants/administrators to use the building and its facilities correctly, being motivated to reduce the energy consumption

Choosing the correct way how the building should operate both as a whole and at the level of individual blocks

Designating a representative to monitor the execution of thermal refurbishment works in case of building refurbishment

Permanent recording of energy consumption, including analysis of energy bills

periodic review of energy supply contracts and their amendment, if necessary

providing energy consultancy services from specialized companies (which also ensure the proper maintenance of the building facilities)

B - Local measures to reduce the energy consumption

dismantling and washing of heat emitting equipment (heaters, fan-convectors, etc.)

removing objects that prevent the heat from the radiators from reaching the room

introducing a reflective surface between the radiator and the expansion wall that reflects the heat back into the room

thermo-hydraulic balancing of the heating units

replacing sanitary fixtures

hydraulic balancing of the hot running water distribution network

air balancing of air distribution networks
correction of the settings of the automatic operating parameters of the equipment

Estimated total costs (excluding VAT) of the measures proposed to increase the energy performance ≥ 100.000 EUR:

Estimated total energy savings: $\geq 60\%$

Estimated investment recovery duration: ≥ 10 years

List of the steps that need to be taken to implement the energy-saving and environmental performance improvement measures:

Envelope renovation

Carpentry replacement

Thermal insulation of the attic floor and of the floor over the thermal channel

Use of energy from renewable sources

Installations modernization, implementation of ventilation with heat recovery

Information on financial incentives or other funding opportunities:

European Funds

Government Funds

Own Funds

TECHNICAL INFORMATION REGARDING THE CERTIFIED BUILDING

ANNEX 2 to the Energy Performance Certificate no. 000131/ 550311

for the BUILDING/BUILDING BLOCK/APARTMENT from Siblu, str. Electricienilor no. 1, Sibiu County

A.DATAREGARDING THECERTIFIED BUILDING

Type of building: existing

Construction year: 1966

Building category: educational establishment – school/highschool/college

Climate zone where the building is located: III

Wind energy area where the building is located: IV

Height regime of the building: groundfloor, 2 floors

Constructive structure of the building:

- structural masonry walls

- reinforced concrete frames

Number and type of apartments/building blocks/thermal areas and floor reference areas:

Type of apart/block/area destination		Reference area of an apart/block/thermal area ZTC or ZTU [sqm]		Number of similar apartments/blocks/thermal area		Total reference area/type [sqm]	
C1	C2	C1	C2	C1	C2	C1	C2
ZTC.1.1		3580		1		3580	
ZTU1		1145		1		1145	
ZTU2		324.8		1		324.8	
TOTAL				3		5049.8	
<p>Total reference area of the floor of the building or building block: 3580.00 sqm Reference interior volume V, of the building/building block: 12678.00 m³</p>							

o Geometric and thermal characteristics of the envelope:

Type of construction element		Thermal strength corrected		Thermal strength corrected		Area	
		calculated [m²K/W]		standard [m²K/W]		[m²]	
C1	C2	C1	C2	C1	C2	C1	C2
R1.	PE1	0,37				474,1	
R2.	PE1	0,38				281,4	
R3.	PE1	0,36				487,4	
R4.	PE1	0,38				375,2	
R5.	PI- _{extic}	0,58		5		1145	
R6.	PI- _{ground}	0,5		2,9		972,1	
R7.	PI- _{technical channel}	0,35		2,9		324,8	
R8.	FE-PVC	0,43		0,5		1084,2	
R9.	UE-PVC	0,41		0,5		42,5	
R10.	PI-central	0,26		5		151,9	
Total envelope area			S_E [m²]		5348,6		

Building form factor S_g/V : 0.42 m⁻¹

Details of the annual specific consumption of primary energy [kWh/m² years, respectively of annual specific equivalent CO₂ emissions [kgCo₂/m².year]

Type of installation system	Real building			Reference building	
	Specific consumption Primary/linear energy	CO ₂ equivalent annual specific emissions	Energy performance class	Primary energy specific consumption	CO ₂ equivalent annual specific emissions
Heating	51.0/60.3	12.1	B	82.7	13.1
Hot running water	14.7/17.4	3.5	B		
Cooling					
<u>Mechanical ventilation</u>	15.6/ 39.0	4.2	E		
Lighting	9.4 / 23.5	2.5	C		
TOTAL/CLASS	90.7/ 140.2	22.2	C		

Standard number of persons inside the building/building block: 609.00 people

B. DATA REGARDING THE INTERIOR HEATING SYSTEM

Existence of the heating system: yes, functional

Current energy source for heating the spaces: own source (individual system, natural gas fuel)

Type of heating system: heating with static bodies power plant

Type of static body	Number of static bodies (pcs)			nominal thermal power [kW] for the heating flow/return temperature/interior temperature ofCelsius degrees
	Area	In the living/work space	In the common spaces	
steel	ZTC1.1	175		270 [kW] 55/45 20 [°C]
TOTAL		175		270

- Type of thermal agent distribution: lower
- Calculation heat requirement (necessary thermal energy): 539.32kW
- Energy necessary for humidification: 0.00 kW
- Total thermal power installed for heating: 500/kW(thermal/electric)
- Connection to the centralized heating source: standard diameter – 0 mm
available pressure: 0 mmCA
- Heating meter: doesnot exist
- Costs allocator: doesnot exist
- Thermal and hydraulic adjustment elements:
at connection/heating source level at columns level
at static bodies level

Total length of the distribution network located in unheated spaces: 0.00 m

Unheated space denomination	Section diameter (mm) / Section length(m)								
ZTU1- attic ZTU2–technical channel									

Total standard flow of the heating agent: 23840.10 l/h

Occupation level of the heated space (operating schedule of the heating facility)

Area	Work day	Weekend day		
Hours	10			
Interior temperature (°C)	20			

C. DATA REGARDING THE HOT RUNNING WATER SYSTEM

Does the hot running water system exist? Yes, it is operating

Energy source for preparing hot running water: own source (individual thermal system with natural gas fuel)

Type of equipments for preparing the hot running water: boiler with accumulation (number/volume) 1/2000 l

Number of sanitary items per types:

Washbasin	19	Bathtub	0
Washers	0	WC	26
Bidets	0	Dishwasher	0
Urinals	9	Washing machine	0
Shower			

Total number of hot running water consumption points: 19

Thermal power necessary for preparing the hot running water: 0 kW

Maximum thermal power installed for preparing the hot running water: 0 kW

Connection to the heating centralized system:

- nominal diameter: 0 mm

- necessary pressure: 0 mmCA

The hot running water recirculation pipe: does not exist

The general hot running water meter: does not exist

Debit metres of the consumption points: do not exist

D. INFORMATION REGARDING THE COOLING/AIR CONDITIONING SYSTEM

Does the cooling/air conditioning system exist: no – ignore the energy consumption for cooling/air conditioning

Time of one year when the interior temperature exceeds the free comfort temperature during the summer: 241 hrs

Reference volume of the air-conditioned area: 11814 m³

Average nominal value of the EER performance coefficient of the cooling source: 0.00

The coldness necessary for cooling (refrigeration capacity): 0.00 kW

The coldness necessary for dehumidification (latent power): 0.00 kW

Total refrigeration power installed in the building: 0.00 Kw

E. INFORMATION REGARDING THE MECHANICAL VENTILATION SYSTEM

Does the mechanical ventilation system exist: No, ignore the electricity for residential buildings, respectively a virtual consumption of electricity is requested for non-residential buildings (acc.to Mc001 provisions, chapter 5.3)

Minimum fresh air flow for ventilation according to the legal rules, under standard terms/ensured by the mechanical ventilation system from the building: 0 m³/h

Is there a heat recoverer? No

F. INFORMATION REGARDING THE LIGHTING SYSTEM

Does the lighting system exist: Yes, it is functional

Type of control/adjustment system of the lighting system: no adjustment (on/off)

Type of lighting system: fluorescent

Electrical network condition/ lighting conductors network condition: Used

Total electricity necessary for the lighting system, corresponding to the normal use of the spaces/insuring the normal lighting level: 10.00 kW

Total installed electricity of the lighting system: 10.00 kW

G. INFORMATION REGARDING THE ENERGY RENEWABLE SOURCES

Solar thermal panel system: does not exist

Photovoltaic panels systems: does not exist

Heat pump: does not exist

Biomass usage system: does not exist

Wind farm: does not exist

Thermal energy exported: 0.00 kWh/year (produced on-site)

Electricity exported: 0.00 kWh/year (produced on-site)

Thermal energy exported from renewable sources: 0.00 kWh/year (produced on-site)

Electricity exported from renewable sources: 0.00 kWh/year (produced on-site)

Primary energy indicator EP_p : 140.3 kWh ($m^2.a$)

RER_p indicator: 9.14 %

CO₂ emissions indicator: 22.2 kgCO₂ ($m^2.a$)

Drafted by,

Buildings energy auditor

Cruciat Radu-Iuliu

H.SITE PHOTOS

